

Lafayette Gas Safety Meeting


April 25, 2019



Together, Building
a Better California



Enterprise and Integrity Management Risk Views






Event-Based Risk Framework Overview

Bowtie analysis helps us understand:

- Risk drivers and the controls to reduce their frequency
- Risk consequences and the controls to reduce their impact



A consistently applied event-based risk framework in conjunction with data-driven risk modelling supports:

- Mutually-exclusive risks where risk models do not overlap
- Visibility to drivers and controls that impact multiple risks
- Ability to prioritize controls based on comprehensive view of impact and effectiveness



Transmission Pipe Risk Model

- **1 million** dynamic segments
- **25** sub-threats (excluding plastic transmission pipe)
- **Semi-Quantitative:**
 - uses common, proportional units for Likelihood of Failure & Safety Consequence
 - uses Qualitative scores for Reliability and Environmental Consequence
- **Risk of ruptures (loss of containment) – excludes non-rupture scenarios**

Steel Pipe External Corrosion (EC)	Steel Pipe Internal Corrosion (IC)	Steel Pipe Stress Corrosion Cracking (SCC)	Steel Pipe Manufacturing and Construction	Steel Pipe Equipment and Incorrect Operations	Steel Pipe Third-Party Damage (TPD)	Steel Pipe Weather-related and Outside Forces (WROF)	Plastic Pipe threats	
External Corrosion	Internal Corrosion	High-pH Axial SCC	Manufacturing Seam defect	Over-pressure due to Equipment Failure	Excavation Damage	Seismic Fault Crossing	Manufacturing	
		Near Neutral-pH Axial SCC	Manufacturing Body defect	Over-pressure due to Incorrect Operations		Slope Instability	Vegetation Impact (Tree root)	Construction
		Circumferential SCC	Construction defect			Liquefaction	Tsunami	Equipment
						Erosion	Third-Party damage	
						Lightning	Incorrect Operations	
						Frost	Weather-related and Outside Forces (WROF)	
						Heavy Rain or Floods		
						Vandalism		
						Arc Strike		



Distribution Risk Model Overview

- **8 million** segments and service points
- **29** sub-threats
- **Quantitative** – uses common, proportional units
- Risk of **leaks** (loss of containment) – excludes non-leaking scenarios
- **Safety** – the key consequence factor used




Corrosion	Excavation	Material & Weld	Incorrect Operation	Natural Force	Other Outside Force	Equipment Failure	Other
Internal	Excavation	Plastic material failure	Crossbore	Earth Movement	Fire/explosion	Equipment malfunction	Other
External			Fusion failure	Earthquake	Rodents	Pipe Dope	
Atmospheric		Metallic material failure	Weld failure	Flood	Previous damage		
		Compression coupling	Incorrect operation	Lightning	Electrical facilities		
			Construction defect	Root damage	Third party		
				Tsunami	Vandalism		
				Other natural forces	Vehicle		




Threat Matrix (Transmission Pipe)

Approved: 07/17/18



availability and the quality of the asset data



--- = Mitigation for Interacting Threat
 TRA# - Risk Register Name

Mitigation Color Key	
Green	Meets or exceeds industry best practices AND controls are adequate
Amber	Partially meets industry best practices OR controls are being strengthened
Red	Does not meet industry best practices AND current controls are not adequate
White	Pending Evaluation
LI	*Not yet implemented



Threat Matrix (Distribution Mains and Services)

Approved: 10/12/2018

	Primary Causes of Failures	Primary Prevention Measures (highest impact on risk reduction - from left to right)						
Time Dependent Threats	External Corrosion DMS15;DMS17;DMS12;DMS3	Inadequate coating Inadequate Cathodic protection Atmospheric conditions	Cathodic Protection	Leak Survey	Asset Replacement			
	Internal Corrosion DMS4	Sulfur Water intrusion	Leak Survey	Leak Repair	Asset Replacement			
	Material or Weld - Plastic DMS5;DMS22;DMS6	Poor resin quality Rock impingement/stress on pipe	Material Specifications	Inspection during Manufacturing	Leak Survey	Asset Replacement		
Stable Threats	Material or Weld - Metallic Pipe DMS23;DMS7;DMS12	Poor quality manufacture Inadequate specifications	Material Specifications	Inspection during Manufacturing	Leak Survey	Asset Replacement	Process Safety	
	Equipment Related DMS25	Age, Obsolescence Incorrect sizing/design	Preventive maintenance	Work Procedures	Training	Asset Replacement		
Time Independent Threats	Excavation Damage DMS8;DMS1;DMS39;DMS2	1 st , 2 nd , 3 rd Party Excavation Damage Inadequate Procedures Human Error	Quality Management	Locating and Marking	One Call System	Public Awareness		
	Incorrect Operations DMS10;DMS11	Human Error Cross Bore Applicant Installed Fusion Joints	Procedures	Process Safety	Training	Operator Qualifications	Quality Management Inspecting during const.	Records
	Natural Forces DMS7;DMS14	Lightning; Flooding Seismic events; Land movement	Design	Label	Emergency Preparedness Procedures	Asset Replacement		
	Other DMS38;DMS37	Vandalism Vehicular damage Overbuilds	Design	Physical Barrier to Asset	Asset Relocation or Replacement			
Loss of Supply	Failure to meet customer demand	Inadequate Capacity Improper Clearances	Long term Investment Planning	Clearance Process and Tools				
Emergency Response	Major Emergency or Disaster	Inadequate First Responder Response Inadequate Dispatch response Inadequate EOC Response Inadequate training	EOC Response	Shut-in Time	Emergency Response	Emergency Shutdown Zones		

availability and the quality of the asset data

complete partial weak


MSI on Color Key

Green = Most improved, fully implemented, O&M done, low risk
 Amber = Partially meets industry best practices OR controls are being strengthened
 Red = Does not meet industry best practices OR controls are not being strengthened
 White = Pending evaluation *Not yet implemented



Transmission Pipe

Risk top-level drivers




¹Values displayed are means of each distribution and are in the units of events/year. Driver frequencies are summed to obtain the Risk event frequency.

²Drivers are modeled using Poisson and Binomial distributions.



Release of Gas with Ignition on Distribution Facilities – Non-Cross Bore



¹Values displayed are means of each distribution and are in the units of events/year. Driver frequencies are summed to obtain the Risk event frequency.

²Drivers are modeled using Poisson and Binomial distributions.



2019 GT&S Risk Placemat

2019 GT&S Rate Case - Risk Mitigation Summary "Placemat"

Risk Category		Loss of Containment						Loss of Supply & Service			Inadequate Response & Recovery							
Threat / Work Classification		Time-Dependent Threats		Stable / Resident Threats		Time Independent Threats		Capacity and / or Reliability Threats			Emergency Response							
		<i>"The threat level may grow over time if unchecked"</i>		<i>"The threat is inherent but does not grow over time unless acted upon by pressure or external load"</i>		<i>"The threat exists outside of the continuum of time"</i>		<i>"Inability to meet our obligation to serve"</i>			<i>"Preparedness to respond to incidents in a timely manner"</i>							
Capital	Expense	External Corrosion, Internal Corrosion and Stress Corrosion Cracking*				Manufacturing Related Defects, Welding / Fabrication Related and Equipment Related*		3rd Party / Mechanical Damage, Incorrect Operations and Weather-Related & Outside Forces*			Physical System Constraints, Equipment Limitations		System Control Limitations, Improper Training and Coordination					
		Corrosion Control Chapter 8 79.1	Direct Assessment Chapter 5 35.3	Vintage Pipe Replacement Chapter 5 40.6	Station Systems and Components Replacement Chapter 7 76.1	19.1	Exposed & Shallow Pipe (including Water and Levee Crossings) Chapter 5 21.7	0.9	Locate & Mark Chapter 9 -	13.2	Capacity Chapter 10 70.0	6.2	Work Requested by Others Chapter 5 27.9	0.7	Gas System Operations Chapter 10 -	22.2		
		Gas Quality Assessments Chapter 7 -	1.0	Hydrostatic Testing Chapter 5 46.0		151.0	Station Rebuilds Chapter 7 44.7	-	Geo-Hazard Monitoring & Mitigation Chapter 5 4.5	2.8	Earthquake Fault Crossing Chapter 5 12.2	1.4	New Business Chapter 10 4.7	-	Class Location Program Chapter 5 5.5	3.3	Valve Automation Chapter 5 29.5	-
		Leak Management Chapter 9 -	6.1	Storage Assessments Chapter 6 -	10.8	Station Assessments & Strength Tests Chapter 7 0.3	7.3	FIMP Implementation and Documentation Chapter 7 -		5.7	Physical Security Chapter 7 9.4		-	LNGICNG Chapter 5 3.7		2.8	Public Awareness Chapter 5 -	4.4
		Storage Well Reworks Chapter 6 160.3	-	Storage Repair & Replace Chapter 6 3.2	-	Storage Controls & Monitoring Chapter 6 14.5	-	Compressor Replacements Chapter 7 21.5		-					-	Valve Program Chapter 5 25.9	0.9	
		In-Line-Inspection Chapter 5 213.5				124.5							SCADA Chapter 10 2.7	-				
		Programs to Enhance Integrity Management Chapter 5 -						14.2										
								Operations & Maintenance Chapter 9 -						46.6				
								Research & Development Chapter 12 -						2.9				
								Other Pipeline Safety and Reliability Pipe Replacements Chapter 5 7.4						4.1				
Capital	Expense							Information Technology Chapter 12 30.4						20.4				
924.9	522.6							Other GT&S Work Chapters 10 and 13 6.1						91.8				
								StanPac Chapters 5, 7, 8, 9 6.0						4.5				
								Gas Gathering Chapter 5 4.0						-				
								Pipe Investigations and Field Engineering Chapter 5 -						8.7				
Capital	Expense																	
46.6	125.4																	



2020 GRC Risk Placemat

Risk Category	LOSS OF CONTAINMENT			LOSS OF SUPPLY & SERVICE	INADEQUATE RESPONSE AND RECOVERY		
Risk Driver Classification	TIME DEPENDENT	STABLE	TIME INDEPENDENT	CAPACITY AND/OR RELIABILITY	EMERGENCY RESPONSE		
Targeted Controls & Mitigations	Aldyl-A Main Replacement Expense \$ - Capital \$ 258.5 CHAPTER 4	Distribution Station Updates Expense \$ - Capital \$ 113.2 CHAPTER 5	Gross Bore Program Expense \$ 29.9 Capital \$ - CHAPTER 4	Distribution System Capacity Expense \$ - Capital \$ 39.4 CHAPTER 9	Emergency Shut Down Zone Valves Expense \$ - Capital \$ 13.6 CHAPTER 4		
		LNG / CNG Upgrades & Maintenance Expense \$ 3.6 Capital \$ 4.1 CHAPTER 5	Locate and Mark Expense \$ 41.1 Capital \$ - CHAPTER 6				
	Corrosion Control Expense \$ 27.5 Capital \$ 18.6 CHAPTER 7	Station Overpressure Protection Enhancement Expense \$ - Capital \$ 13.8 CHAPTER 5					
		SCADA Expense \$ - Capital \$ 29.2 CHAPTER 9					
	Reliability Main Replacement Program Expense \$ - CHAPTER 4 Capital \$ 46.8					Work Requested by Others Expense \$ 6.0 Capital \$ 162.6 CHAPTER 10	Emergency Response Expense \$ - Capital \$ 0.9 CHAPTER 8
	GPRP Main Replacement Expense \$ - CHAPTER 4 Capital \$ 124.7						
	Distribution Integrity Management Program Expense \$ 11.7 CHAPTER 4 Capital \$ -						
	Leak Survey & Repair Expense \$ 66.6 CHAPTER 8 Capital \$ 38.3						
	Operations & Maintenance Expense \$ 45.6 CHAPTER 6 Capital \$ -						
	Field Services Expense \$ 45.5 CHAPTER 6 Capital \$ 2.0						
	Gas System Operations Expense \$ 15.2 CHAPTER 9 Capital \$ -						
	Other Construction Expense \$ - CHAPTER 4 Capital \$ 68.8						
	Support Work Expense \$ 73.4 Capital \$ 15.2	Technology and Other Distribution Support Expense \$ 78.4 CHAPTER 11 Capital \$ 15.2					
	Expense Capital \$ 293.7 \$ 934.4						



Risk Factors and Parameters Considered for Trees in the Lafayette area (207 total)

- The predominant risk factors in PG&E's risk model is 1) the horizontal proximity the tree is to the pipeline, and 2) the depth of cover above the pipeline.
- Contributing risk parameters that are all important and increase the risk profile of the pipeline are as follows:

Pipeline Threats	Weather Related and Outside Forces – Landslides, erosion, wind, flooding, lightning are factors to consider where tree roots affect buried pipelines. When a tree is uprooted or is in close proximity to the pipeline, large tree roots entangled around a pipeline can potentially pull on, or even extract a pipeline from the ground. Lightning strikes often involve trees, and can provide the mechanism for increasing the susceptibility of lightning damage to the buried pipeline. Lightning can strike a tree and propagate through the roots to the soil surrounding a pipeline.
	Corrosion - Buried pipelines rely upon external coating and cathodic protection (CP), to protect the pipe and mitigate external corrosion. Tree roots can damage external protective coatings by creating coating holidays (coating voids or gaps), growing against the pipe, and penetrating between the coating and the pipe surface. Depending upon the tree root system and/or coating systems, disbonded (but still intact) coating can also prevent CP from adequately protecting the pipe surface in a phenomenon known as CP shielding. Shielding can be exacerbated by the presence of tree root entanglements surrounding the pipe surface. Therefore, tree roots can negatively affect two barriers used to protect the external pipe surface – external coatings and cathodic protection.
	Excavation Damage - Independent studies have identified that one of the most significant factors contributing to the threat of someone inadvertently striking and damaging a pipeline (referred to as 3rd Party Damage and includes anyone knowingly or unknowingly performing an excavation along the ROW) is the ability of the public to identify and recognize a pipeline ROW. Heavy vegetation within the ROW prevents corridor recognition and contributes to the potential for inadvertent impact of a pipeline by a 3rd party excavator.
Damage Prevention	Impact on ability to perform routine maintenance and monitoring
	Reduction of recognizable ROW
	Reduction in damage prevention capabilities
Emergency Response	Increased time frame required in emergency response and pipeline integrity investigations



Risk Factors and Parameters Considered for Trees in Lafayette (207 total), cont.

- Weather Related and Outside Force and Excavation threats are a significant risk contributor to the pipeline since these threats are more difficult to manage since they are a time independent threat which is cannot be as easily monitored or predicted as other time dependent threats like corrosion.
- **Supporting Evidence:** The development of PG&E's risk model was informed by industry recommended practices (PIPA – Pipelines and Informed Planning Alliance), benchmarking against other utilities in the industry and independent research from a tree root study where locations were excavated and data collected to inform the risk parameters of the model.



Planned Project Information

Planned Transmission Pipeline Projects in Lafayette (as of April 2019)			
Line	Approximate Location of Pipeline Project	Footage of Pipeline and Number of Valves	Planned Date of Execution
L-191B	McGraw Lane to Meadowlark Court	In-Line Inspection ~1,200 feet	2019
DFM 3001-01	St. Marys Road between South Lucille Lane and Rohrer Drive and 2nd Street and Golden Gate Way	Replace ~450 feet	2019
DREG5203	Near Intersection of Olympic Oaks Drive and Olympic Boulevard	1 valve	2019
L-191-1	Olympic Boulevard and Reliez Valley Road	Replace ~600 feet 1 automated valve 11 manual valves	2019 - 2020
L-191-1	Near Intersection of Reliez Station Road and Olympic Blvd	ILI Receiver ~83 feet 1 valve	2019 - 2020
L-191-1	Near Intersection of Olympic Oaks Drive and Olympic Boulevard	Replace ~50 feet	2021
L-191-1	Near Intersection of Moraga Boulevard and 3rd Street	Replace ~1,100 feet	2021

Just 121