

PACIFIC GAS AND ELECTRIC COMPANY

CHAPTER 4

GAS TRANSMISSION VALVE AUTOMATION PROGRAM

PACIFIC GAS AND ELECTRIC COMPANY
CHAPTER 4
GAS TRANSMISSION VALVE AUTOMATION PROGRAM

TABLE OF CONTENTS

A. Introduction.....	4-1
1. Valve Automation Proposal.....	4-2
a. Installation of Automated Valves.....	4-2
b. SCADA System Enhancements.....	4-5
c. Valve Automation Program Cost Request	4-7
B. Valve Automation Program.....	4-8
1. Scope of Valve Automation Program	4-8
2. Pipe Segment Selection for Automation.....	4-9
a. Decision Trees.....	4-10
b. Key Factors in Segment Selection.....	4-12
(1) DOT Defined Gas Transmission Pipe	4-12
(2) Population Density – Class 3 and 4 Locations and HCAs	4-13
(3) Potential Impact Radius	4-15
c. Pipelines in High Population Density Areas.....	4-16
d. Pipelines in Active Earthquake Fault Zones.....	4-18
(1) Earthquake Fault Automation Plan Overview	4-18
(2) Active Fault.....	4-19
(3) Threat of Rupture	4-19
(4) Gas Transmission Pipeline Enhancement Program	4-20
3. Design Details of Pipe Segment Automation.....	4-21
a. Valve Spacing Determination.....	4-21
b. RCV vs. ASV Usage Determination.....	4-24
(1) Remote Controlled Valves.....	4-24
(2) Automatic Shut-off Valves	4-25

PACIFIC GAS AND ELECTRIC COMPANY
CHAPTER 4
GAS TRANSMISSION VALVE AUTOMATION PROGRAM

TABLE OF CONTENTS

(CONTINUED)

(3) Continuity of Service Impact.....	4-26
C. Scope of SCADA Enhancements	4-26
D. Program Justification	4-29
1. Emergency Preparedness and Facilitation of Emergency Response.....	4-29
2. The Pipeline Industry and NTSB Recommendations	4-30
3. Evaluation of Valve Automation Program by EN Engineering	4-32
E. Background on Industry Usage of Automated Valves	4-33
1. Federal Regulations	4-33
2. Domestic Natural Gas Transmission Industry Practice	4-34
a. Industry Perspective on Automated Valves	4-35
b. Industry Perspective on Automatic Shut-Off Valves	4-35
c. Industry Perspective on Remote Controlled Valves.....	4-36
3. International Natural Gas Transmission Industry Practice	4-36
F. Project Phases	4-37
1. Pipe Segment Phase Prioritization.....	4-37
2. Description of Phase 1 Program (2011-2014).....	4-38
3. Description of Phase 2A.....	4-42
4. Description of Phase 2B.....	4-42
G. Specific Projects Scope Determination.....	4-42
1. Phase 1 Valve Automation	4-42
a. Determination of Specific Automation Segments.....	4-42
b. Determination of Pipe Segment Automation Requirements.....	4-43
c. Determination of Specific Projects	4-44

PACIFIC GAS AND ELECTRIC COMPANY
CHAPTER 4
GAS TRANSMISSION VALVE AUTOMATION PROGRAM

TABLE OF CONTENTS

(CONTINUED)

d. Determination of Specific Project Design Requirements.....	4-45
2. Phase 1 Metering.....	4-48
H. Program Changes Based on CPUC Workshops and Feedback.....	4-49
I. Project Cost Estimating Methodology.....	4-49
1. General	4-49
2. Project Estimating Approach	4-50
3. Unit Cost Approach	4-50
4. Description of Typical Valve Automation Types and Associated Costs.....	4-51
a. Automation of an Existing Valve	4-51
b. Replacement of Existing Valve at Same Location	4-51
c. Installation of New Valve.....	4-52
d. Upgrade of Existing Automated Valve	4-52
e. Automation or Replacement of Existing Valve in Vault	4-52
5. Cost Basis Assumptions.....	4-53
a. Economic Assumptions.....	4-53
b. Exclusions.....	4-53
6. Direct Cost	4-54
a. Material	4-54
(1) Valves	4-54
(2) Pipe and Fittings.....	4-54
(3) Actuators	4-54
(4) SCADA.....	4-54
b. Construction Labor	4-55

PACIFIC GAS AND ELECTRIC COMPANY
CHAPTER 4
GAS TRANSMISSION VALVE AUTOMATION PROGRAM

TABLE OF CONTENTS

(CONTINUED)

(1) Pipeline Contractors	4-55
(2) Restoration	4-55
(3) Vaults	4-55
(4) Clearance Cost.....	4-56
(5) Land, Permit, Environmental and Safety	4-56
(6) Power Supply, Telecommunication, and SCADA.....	4-56
(7) District Regulator Station Retrofits	4-56
(8) Adjacent Valve Projects	4-57
c. Engineering and Other Non-Construction Labor	4-57
(1) Engineering	4-57
(2) Project Management	4-57
(3) Customer Outreach	4-57
(4) Program Management Office	4-58
7. Indirect Cost	4-58
8. Contingency	4-59
9. Metering Cost Estimates	4-59
10. Other Cost Estimates	4-59
a. SCADA Enhancement Projects	4-59
b. Operation and Maintenance Additions	4-60
J. Summary of Program Costs	4-62
1. Cost Forecast Summary (Phase 1)	4-62
2. Forecast Capital Expenditures (Phase 1).....	4-63
a. Valve Automation Projects.....	4-63

PACIFIC GAS AND ELECTRIC COMPANY
CHAPTER 4
GAS TRANSMISSION VALVE AUTOMATION PROGRAM

TABLE OF CONTENTS

(CONTINUED)

b. Other Capital Projects.....	4-64
3. Forecast Expenses (Phase 1)	4-65
a. Valve Automation Program Development	4-65
b. SCADA Enhancements and Valve Automation Expense Projects	4-65
c. Reoccurring Operations and Maintenance Costs (M&C, Gas Control)	4-66
K. Project Implementation (Phase 1)	4-66
1. Scheduling of Work	4-66
2. Implementation Schedule.....	4-67
3. Need for Plan Modifications and Work Re-Prioritization.....	4-68
4. Quality Assurance and Quality Control	4-68
L. Conclusion.....	4-69

1 **PACIFIC GAS AND ELECTRIC COMPANY**
2 **CHAPTER 4**
3 **GAS TRANSMISSION VALVE AUTOMATION PROGRAM**

4 **A. Introduction**

5 The purpose of this chapter is to describe Pacific Gas and Electric
6 Company's (PG&E) Valve Automation Program as part of the Pipeline Safety
7 Enhancement Plan (or Implementation Plan) required by California Public
8 Utilities Commission (CPUC or Commission) Decision 11-06-017. The Valve
9 Automation Program is a critical component of PG&E's plan to modernize its
10 infrastructure and increase public safety. If the Commission approves the Valve
11 Automation Program, the majority of gas transmission pipelines in populated
12 areas in PG&E's service territory, including all of the larger diameter and higher
13 pressure lines, will be able to be quickly isolated in the event of a pipeline
14 rupture, facilitating emergency response and reducing potential threat and
15 impact on the public and property.

16 The Valve Automation Program will greatly expand PG&E's use of
17 automated pipeline system isolation valves (automated valves). There are
18 two types of automated valves included in the Valve Automation Program, each
19 used for a specific purpose: (1) Remote Control Valves (RCV); and
20 (2) Automatic Shut-off Valves (ASV). PG&E will install RCVs, which are
21 remotely triggered by operators in PG&E's Gas Control Center, in heavily
22 populated areas. Due to the unique threat posed by pipelines crossing
23 earthquake faults, PG&E will install ASVs, which are automatically triggered by
24 local controls at the valve site, on pipelines in populated areas that cross active
25 earthquake faults where the fault poses a significant threat to the pipeline. Both
26 types of automated valves, RCVs and ASVs, will provide for the quick shutoff of
27 gas to pipeline segments in the event of a pipeline rupture. All new automated
28 shut-off valves will be capable of operating in RCV or ASV mode, thus enabling
29 PG&E to convert the operation of the valve to a different mode if warranted in
30 the future.

31 PG&E proposes to prioritize installation of automated valves on pipeline
32 segments based on population density (i.e., class location, presence of High
33 Consequence Areas (HCA), and the Potential Impact Radius (PIR) of the

1 pipeline) and criteria for earthquake fault crossings. In addition, as part of the
2 Valve Automation Program, PG&E will enhance its Supervisory Control and
3 Data Acquisition (SCADA) system to provide the information and tools
4 necessary for operators in its Gas Control Center to better identify and more
5 quickly respond to isolate sections of pipeline if a pipeline rupture occurs. The
6 evaluation of where to add automated pipeline isolation capability, and the
7 determination of the Phase 1 projects and their work scope, was done in close
8 collaboration with EN Engineering (ENE), an engineering firm with extensive
9 knowledge in gas transmission engineering and integrity management.

10 PG&E is proposing to implement the Valve Automation Program in
11 two phases. This chapter presents the locations identified for Phase 1
12 implementation (2011-2014), project cost estimates for these installations, and
13 their implementation schedule. In addition, this document provides a preliminary
14 overview for Phase 2 implementation (2015 and beyond). PG&E requests
15 conceptual approval of the overall Valve Automation Program in the
16 Implementation Plan. However, we are only seeking cost recovery for Phase 1
17 of the Valve Automation Program at this time. The scope, schedule and cost
18 recovery for Phase 2 of the Valve Automation Program, commencing January 1,
19 2015, will be addressed in a future Commission filing.

20 **1. Valve Automation Proposal**

21 The Valve Automation Program consists of two elements:

22 (1) installation of automated valves; and (2) SCADA system enhancements.

23 **a. Installation of Automated Valves**

24 The objective of the Valve Automation Program is to enable PG&E
25 to either remotely, or with local automatic control, quickly shut off the
26 flow of gas in response to a gas pipeline rupture. Under the design
27 criteria for the program, automated valves are spaced so that in the
28 event of a full pipeline rupture, pressure in the pipe will dissipate in
29 minutes following valve closure. The Valve Automation Program will
30 also replace valves where needed to assure "piggability" in the pipeline
31 system.

1 The objective of the Valve Automation Program is to significantly
2 shorten the time required to isolate and blowdown^[1] pipe segments
3 containing large quantities of high pressure natural gas in populated
4 areas in the event a pipeline rupture occurs. The key benefit of this
5 reduction in response time is to enable first responders to mobilize and
6 quickly take action to address the rupture event and its consequences.

7 The target of the Valve Automation Program is the retrofit of existing
8 gas transmission pipelines. However, PG&E will also evaluate all new
9 pipeline projects and replacement pipeline projects for valve automation
10 based upon the decision-making criteria in this program, plus the
11 following additional criteria: (1) all future projects will be evaluated for
12 valve automation based upon anticipated future class location; and
13 (2) pipe projects for existing Class 1 and 2 HCAs will automate manual
14 valves required by these projects based upon the more inclusive Class 3
15 valve automation criteria. This acknowledges the fact that automation
16 can be accomplished at lower incremental cost at the time of new
17 pipeline installation, and achieves the greatest amount of safety value
18 for the capital expenditures.

19 The Valve Automation Program will be implemented in a phased
20 approach. During Phase 1 (2011-2014), PG&E will replace, automate
21 and upgrade 228 isolation valves. The Valve Automation Program
22 “launch” will commence in 2011 with 20 new automated valve
23 installations on the San Francisco Peninsula from Milpitas to
24 San Francisco. At completion of Phase 1, the Valve Automation
25 Program will result in approximately 410 miles of gas transmission
26 pipeline in Class 3 and 4 areas being equipped with automated isolation
27 valves, typically at 5-8 mile intervals, and automatic shut-off valves
28 being installed on 9 pipe segments traversing 16 active earthquake fault
29 crossings. Phase 2 will include the automation of roughly 330 additional
30 valves.

31 Phase 1 will focus on pipelines in Class 4 areas, and larger
32 diameter, higher pressure pipelines located in highly populated Class 3

[1] “Blowdown” is the process where gas in the pipeline is evacuated until the gas pressure reaches atmospheric pressure.


1 areas. The following map highlights the core area of Phase 1 work.
 2 Approximately 60 percent of the Phase 1 automation miles are located
 3 in the Peninsula, South East Bay and South Bay. Other significant
 4 areas of work include pipelines in and around Sacramento, Stockton,
 5 Fairfield, Bakersfield and Morgan Hill, and the Highway 4 corridor
 6 between Antioch and Highway 80 in the East Bay. All sites identified by
 7 symbols (i.e., circles, squares and triangles) in Figure 4-1 are locations
 8 where specific types of valve automation work will be implemented as
 9 part of Phase 1. A larger scale map of this area is provided as
 10 Attachment 4A.

**FIGURE 4-1
 PACIFIC GAS AND ELECTRIC COMPANY
 MAP OF PHASE 1 VALVE AUTOMATION**



1 Figure 4-2 illustrates a typical pipeline station facility containing both
2 manual and automated valves. The photo shows two automated and
3 one manual valve, and the instrumentation and controls for the
4 automated valves.

**FIGURE 4-2
PACIFIC GAS AND ELECTRIC COMPANY
PHOTO OF AUTOMATED VALVES**



5 Automated valves have equipment that provide for the valve to be
6 opened and closed without a person having to physically be at the valve
7 site. To automate an existing manual valve, the manual gear operator
8 must be removed and replaced by equipment (i.e., valve actuator and
9 controls) that provides for automated operation. Not all existing valves
10 can be automated due to their type or how they were originally installed.
11 In these cases, the valve needs to be replaced prior to being automated.

12 All valves being installed by the Valve Automation Program have
13 both RCV and ASV capability. Valves termed as RCVs have the ASV
14 functionality disabled due to risks discussed in Section B.3.b of this
15 Chapter, "RCV vs. ASV Usage Determination." ASVs are valves that
16 have both RCV and ASV functionality enabled.

17 **b. SCADA System Enhancements**

18 Automated valves provide a mechanism for quickly isolating pipeline
19 segments in the event of a rupture, but this capability can only be fully

1 leveraged if Gas Control operators have the proper control systems and
2 training programs in place to monitor the system, quickly assess
3 abnormal and emergency conditions, and take appropriate actions in
4 response to an incident. The Valve Automation Program includes
5 development and deployment of systems and technologies to provide
6 early warning of events, while preventing false valve closures. To
7 ensure proper use of the RCV/ASVs, PG&E will provide Gas Control
8 operators with additional information, tools, and training to allow for early
9 detection and quick response to pipeline rupture events. These will
10 include:

- 11 1. Additional SCADA monitoring points for pressures and flows to
12 enhance understanding of pipeline dynamics.
- 13 2. Detailed SCADA viewing tools that provide a comprehensive
14 understanding of individual pipeline conditions in real-time and the
15 potential effects (e.g., downstream pressures and flows) if a pipeline
16 segment is isolated, as well as provide increased understanding of
17 pipeline configuration and constraints.
- 18 3. Specific pipeline segment shutdown protocols to provide clear
19 instructions on actions to be taken to quickly and effectively isolate a
20 segment.
- 21 4. Situational awareness tools, which utilize advanced composite
22 alarming, and best practice alarm management methodology to
23 highlight issues requiring immediate Gas Operator action.
- 24 5. Interactive tools that will allow Gas Operators to quickly access GIS
25 physical pipeline information in relationship to SCADA points, and to
26 geographically locate SCADA points.
- 27 6. Training simulation tools to prepare Gas Operators for potential
28 pipeline rupture scenarios.

29 In addition, to ensure effective execution of these actions, and to
30 identify additional SCADA improvement opportunities, PG&E will act
31 upon the suggestion in the Independent Review Panel (IRP) Report^[2]
32 to have an external party review PG&E's gas SCADA system coupled

[2] The IRP Report dated June 8, 2011 was revised on June 24, 2011.

1 with a best practices review of SCADA systems and their usage within
 2 other gas pipeline companies and related industries. This will include an
 3 evaluation of whether the installation of additional SCADA monitoring
 4 points above what is already proposed is warranted. PG&E will
 5 continually assess the effectiveness of its SCADA and control systems,
 6 including the new tools and system modifications listed above.
 7 Continuous improvements will be made to the tools and information to
 8 ensure that controllers are able to make the best informed operating
 9 decisions.

10 **c. Valve Automation Program Cost Request**

11 PG&E requests that the CPUC adopt PG&E's 2011-2014 (Phase 1)
 12 Valve Automation Program capital expenditure and expense forecasts,
 13 as shown in Table 4-1 below, as reasonable.

**TABLE 4-1
 PACIFIC GAS AND ELECTRIC COMPANY
 VALVE AUTOMATION PROGRAM REQUEST
 \$ IN MILLIONS (NOMINAL)**

Line No.	Work Description – MAT Code	2011(a)	2012	2013	2014	Total
1	<u>Capital Expenditure Request</u>					
2	Valve Automation – 2H3	\$13.6	\$33.4	\$43.2	\$22.5	\$112.7
3	Valve Automation-StanPAC – 44A	–	2.0	4.6	–	6.6
4	Flow Meter Installations – 2H3	–	3.9	5.3	3.3	12.5
5	SCADA Enhancements – 2H3	0.1	0.2	0.2	0.2	0.7
6	Valve Automation – Total Capital Expenditures	\$13.7	\$39.5	\$53.3	\$26.0	\$132.5
7	<u>Expense Request</u>					
8	SCADA Enhancements – KE4	\$0.8	\$1.8	\$1.8	\$2.2	\$6.6
9	Reoccurring Operations and Maintenance – KE4	–	0.8	1.3	1.6	3.7
10	Program Planning and Development – KEX	0.8	–	–	–	0.8
11	Valve Automation – Total Expenses	\$1.6	\$2.6	\$3.1	\$3.8	\$11.1
12	Valve Automation Total (Capital and Expense)	\$15.3	\$42.1	\$56.4	\$29.8	\$143.6

(a) The 2011 expenses and capital related costs (including depreciation, taxes and return) for capital projects forecast to be operational in 2011 will be funded by shareholders, as described in Chapter 8.

1 B. Valve Automation Program

2 1. Scope of Valve Automation Program

3 PG&E has selected the pipelines and pipe segments for automated
4 isolation capability where automated isolation will have the greatest impact
5 on minimizing risk related to a pipeline rupture event.

6 Automated valves do not have any ability to prevent a rupture event
7 from occurring or to minimize the consequences from the initial burst of
8 energy following a pipeline rupture. However, risk mitigation will occur by
9 quickly isolating and stopping the flow of gas to the atmosphere following a
10 rupture event. The focus of the Valve Automation Program is on the
11 potential benefits to the public and emergency responders, particularly those
12 related to minimizing property damage, which can be achieved by a quick
13 isolation of the natural gas fuel source.

14 Risk is a mathematical product of the likelihood or probability of an event
15 occurring and the consequences or results should the event occur. The
16 probability and consequence of an extended duration natural gas fire from a
17 pipeline rupture are made up of various components.

18 The **probability** of the event occurring is a function of the likelihood of:

- 19 • A pipe failure.
- 20 • The failure results in the pipe rupturing.
- 21 • The released gas at the rupture site ignites.

22 The **consequence** of the event is a function of:

- 23 • The population density and type of structures and infrastructure in the
24 surrounding area.
- 25 • The intensity of the ignited flame at the rupture location.[3]
- 26 • The time required to isolate and blow down the pipe segment.

[3] The potential for the gas released during a rupture event to ignite is not a controllable parameter, and is therefore not addressed in any aspect of PG&E's Implementation Plan. Ignition probability for a pipeline rupture is greater in populated areas where there are more ignition sources. The probability of ignition is estimated to be approximately 30 percent for a highly populated area. Ignition probability based upon EN Engineering Technical Paper, "Ignition Probability for Natural Gas Pipelines", dated January 21, 2008.

- The combustible fire threat in the area and the ability of emergency resources to respond to the fire.

The Pipeline Modernization Program portion of the Implementation Plan, described in Chapter 3, is focused on minimizing the probability of a pipe failure. The Pipeline Modernization Program places a priority on older vintage pipes in populated areas.

The Valve Automation Program works in tandem with the Pipeline Modernization Program by having as its primary focus those areas where the potential consequences are greatest, and on those pipelines which—given a rupture and gas ignition—would create the highest intensity flame. Additionally, the Valve Automation Program puts an emphasis on automatic isolation of pipe segments that cross active earthquake faults to mitigate potential consequences at those locations that are at the highest risk of pipe failure in an earthquake event. The SCADA enhancements portion of the Valve Automation Program also addresses consequence by enhancing identification and decision making and shortening the time required to isolate a pipeline segment after a pipeline rupture.

2. Pipe Segment Selection for Automation

PG&E has created two decision trees, one based on population density and the other based on earthquake fault crossings, to assist the Company's engineers in determining which pipe segments should be equipped with automated isolation capability as part of the full Valve Automation Program (Phases 1 and 2). In order to mitigate consequences in the event of a pipeline rupture, PG&E recommends installing automated pipeline isolation capability on Department of Transportation (DOT) defined gas transmission pipeline segments within Class 3 and 4 areas that exceed minimum threshold criteria for pipe size and operating pressure as defined using a PIR calculation. For higher populated areas (i.e., Class 3 HCA and Class 4 areas), the minimum threshold criteria are reduced to recognize the higher potential consequence.


In addition, PG&E recommends installing a higher level of automated isolation on certain pipeline earthquake fault crossings in populated areas. These would be DOT defined gas transmission pipelines within Class 3

1 and 4 areas and Class 1 and 2 HCAs that exceed minimum threshold
2 criteria for pipe size and operating pressure, and cross active faults that
3 have a significant probability of rupturing a pipeline under maximum
4 anticipated seismic event conditions. Active earthquake faults are defined
5 per the Alquist-Priolo Fault Zoning Act. A more detailed description is
6 provided in Section 2.d.(2) below.

7 **a. Decision Trees**

8 Figure 4-3 is the decision tree that evaluates high population density
9 and Figure 4-4 is the decision tree that evaluates earthquake fault
10 crossings. Section B.2.b., below, includes a detailed description of the
11 key factors in segment selection including the logic and reasoning
12 behind the development of the decision trees and their specific
13 components. The decision trees were a key tool in determining pipe
14 segments to be automated, but their use was always combined with
15 practical engineering judgment.


**FIGURE 4-3
PACIFIC GAS AND ELECTRIC COMPANY
DECISION TREE – POPULATION DENSITY**



Note: All PG&E Class 4 pipe segments classified as gas transmission have a PIR value greater than 100 feet, therefore all Class 4 pipe segments are identified for automation.

- 1 The Population Density Decision Tree is utilized to identify all
- 2 Phase 1 and Phase 2 pipe segments that will be automated. Phase 1
- 3 scope is focused on all Class 4 identified segments and Class 3,
- 4 PIR > 300 feet, segments that are in areas that have a predominance of
- 5 HCA.

**FIGURE 4-4
PACIFIC GAS AND ELECTRIC COMPANY
DECISION TREE – EARTHQUAKE FAULT CROSSING**



1 Within the “Automate” box of the Earthquake Fault Crossing
 2 Decision Tree are two alternatives. Where fault crossings were deemed
 3 a significant or high threat to the pipeline, ASVs will be installed, which
 4 also have RCV capability. PG&E defines Low Threat in Section 2.d(3)
 5 below. These valves will closely bracket the fault. Where only a low
 6 threat exists, the fault crossing will be able to be isolated with RCVs
 7 installed at the same general spacing as for valves equipped with RCVs
 8 in the Population Density Decision Tree.

9 **b. Key Factors in Segment Selection**

10 **(1) DOT Defined Gas Transmission Pipe**

11 All pipe within PG&E’s gas system with an operating stress
 12 level that exceeds 20 percent Specified Minimum Yield Strength is
 13 classified as DOT defined gas transmission pipe (49 Code of
 14 Federal Regulations (CFR), Section 192.3). All 16-inch and larger
 15 pipelines within PG&E’s system operating at a pressure above

1 240 pounds per square inch gauge (psig) are classified as DOT gas
2 transmission. This represents inclusive criteria to use as a starting
3 point when evaluating where to install automated valves.

4 **(2) Population Density – Class 3 and 4 Locations and HCAs**

5 The value of automated valves to isolate pipe segments in an
6 emergency is greatest in heavily populated, urban environments.
7 Heavily populated areas represent access issues to emergency
8 response personnel fighting a fire and represent the areas where
9 fires would result in greatest safety risks and the largest property
10 damage costs.

11 The federal code governing pipeline safety uses two different
12 means of identifying more heavily populated areas: (1) class
13 location (49 CFR 192.5); and (2) HCAs (49 CFR 192.903). A class
14 location unit is an area 220 yards on either side of the centerline of
15 any continuous 1-mile length of the pipeline. Class 4 is the highest
16 population density and is defined as “any class location unit where
17 buildings with four or more stories above ground are prevalent.”
18 Class 3 is the next highest population density class location and is
19 defined as “any class location unit that has 46 or more buildings
20 intended for human occupancy, or a small well-defined outside area
21 that is occupied by 20 or more persons” for greater than a certain
22 amount of time. Class 2 and 1 locations are the least densely
23 populated areas with 10-45 buildings and less than 10 buildings
24 within a class location unit, respectively.

25 The definition for HCA utilized by PG&E is an area within a
26 potential impact circle containing: (a) 20 or more buildings intended
27 for human occupancy or (b) an “identified site.” Potential impact
28 circle is a circle around a point on the pipeline with a radius equal to
29 the PIR of the pipe at that location. An “identified site” is a location
30 where 20 or more people gather above a certain frequency or
31 facilities occupied by persons who would be difficult to evacuate
32 (e.g., nursing homes). A multi-mile continuous length of Class 3
33 HCA pipeline is generally significantly more heavily populated than
34 a Class 3 non-HCA area.

1 Class 3 and 4 areas capture all heavily populated areas within
2 PG&E's service territory, with the vast majority of pipe within this
3 classification occurring within the greater Bay Area. A total of
4 1,725 miles, approximately 30 percent, of PG&E's gas transmission
5 pipe is located in Class 3 and 4 areas. Within Class 3 and 4 areas,
6 PG&E has 947 miles of HCA pipe.

7 The following photo provides visual representation of a typical
8 Class 3 HCA area.


FIGURE 4-5
PACIFIC GAS AND ELECTRIC COMPANY
CLASS 3 HCA EXAMPLE



9 HCA areas outside of Class 3 and 4 areas are typically
10 localized areas of population within rural environments. They only
11 span short segments of pipeline, typically less than one mile
12 segments, so these have been excluded from the pipeline
13 automated isolation program scope, except for earthquake fault
14 crossings. Because of the nature of these segments within PG&E's
15 gas transmission system, the typical cost per mile required to
16 automate HCA pipe in Class 1 and 2 locations would be

1 approximately six to eight times the cost per mile of Class 3 pipe
2 slated for automation in Phase 1 of the Valve Automation Program.
3 The increased cost per mile is primarily due to the very short
4 lengths of the pipe segments requiring automation (the cost of
5 providing automated isolation capability for an identified segment is
6 independent of its length) and the need to install additional valves
7 for closer spacing intervals. The following photo provides a visual
8 representation of this localized risk.

FIGURE 4-6
PACIFIC GAS AND ELECTRIC COMPANY
CLASS 1 HCA EXAMPLE



9 **(3) Potential Impact Radius**

10 “Potential Impact Radius (PIR) means the radius of a circle
11 within which the potential failure of a pipeline could have significant
12 impact on people or property” (49 CFR 192.903, subpart 4.c). PIR
13 is a function of the pipe diameter and the pressure of the natural
14 gas in the pipe, and is proportional to the heat intensity of the initial
15 flame should a pipeline rupture ignite. The following table defines

1 the required operating pressures for various diameters of pipelines
 2 to have a specific impact radius.[4]

**TABLE 4-2
 PACIFIC GAS AND ELECTRIC COMPANY
 OPERATING PRESSURES FOR VARIOUS PIPE SIZES AND PIR VALUES**

Line No.	Pipe OD (Inches)	PIR=	100'	150'	200'	250'	300'
			Pressure (psig)				
1	6.625		479	1077	1914	2991	4307
2	8.625		282	635	1129	1765	2541
3	10.750		182	409	727	1136	1636
4	12.750		129	291	517	808	1163
5	16.000		82	185	328	513	738
6	20.000		53	118	210	328	473
7	24.000		36	82	146	228	328
8	30.000		23	53	93	146	210
9	36.000		16	36	65	101	146

3 The higher the PIR value, the greater the impact of the ignited
 4 rupture on the ability of emergency response personnel to fight and
 5 contain the fire, and the greater the risk if the natural gas fuel
 6 source is not shut-off quickly. The program scope threshold for
 7 pipe size and operating pressure is defined using PIR value.

8 **c. Pipelines in High Population Density Areas**

9 The Company will install automated pipeline isolation capability on
 10 all DOT defined gas transmission pipelines within Class 3 and 4 areas
 11 where the:

- 12 (1) PIR > 200 feet for pipe segments located in Class 3 areas.
- 13 (2) PIR > 150 feet for pipe segments located in areas with a
 14 predominance of Class 3 HCA.
- 15 (3) PIR >100 feet for pipe segments located in Class 4 areas.

16 For PG&E’s gas transmission pipelines in Class 3 areas, a
 17 PIR > 200 feet would generally translate to automated valves being
 18 installed on 12-inch and larger diameter pipelines. Within Class 3 and 4
 19 areas, PG&E has 774 miles of pipe with a PIR that exceeds 200 feet, of

[4] The equation for calculating PIR is defined in 49 CFR 192.903, subpart 4.c, and is: $PIR \text{ (feet)} = 0.69 \times D \times \sqrt{P}$, where, D = Pipe outside diameter in inches, and P = Maximum Allowable Operating Pressure (MAOP) for the pipeline containing the pipe segment in psig.

1 which 572 miles or nearly 75 percent are also in HCAs. There is an
2 additional 153 miles of Class 3 HCA pipe with a PIR between 150 feet
3 and 200 feet.

4 The base PIR threshold value for Class 3 locations of 200 feet
5 corresponds to a PIR value at which the flame from an ignited pipeline
6 rupture is not anticipated to hinder emergency responder efforts in
7 containing the fire. The value of 200 feet was determined by a fire
8 hazard analysis completed by a third-party consultant with expertise in
9 fire protection and risk analysis. A key fact worth noting is that
10 15 minutes after the rupture, the heat intensity has significantly
11 decreased due to the reduction in natural gas mass release rate at the
12 rupture site. The heat intensity at 15 minutes corresponds to a radius of
13 approximately 60 percent of the initial PIR value.

14 The lower PIR values of 150 feet and 100 feet for Class 3 HCA and
15 Class 4 areas, respectively, were based upon a greater potential for
16 emergency response issues associated with a rupture as the population
17 density increases and the likely increased risk to public safety and
18 property. For example, pipe in the PIR range of 150-200 feet would
19 have to be located in at least a fairly dense residential neighborhood of
20 detached single family homes to be classified as being in an HCA based
21 upon population density. This level of congestion increases the
22 complexity of search and evacuation efforts for first responders and the
23 complexity of firefighting efforts, resulting in PG&E's conservative
24 recommendation to automate these pipelines.

25 For PIR values below 150 feet for Class 3 HCAs and 100 feet in
26 Class 4 areas, firefighting efforts should have the capability to shoot
27 water directly onto an ignited natural gas flame, minimizing the effects of
28 heat from the fire and potential fire damage. These pipes pose
29 significantly fewer firefighting issues. Also, over 70 percent of pipe
30 operating over 60 psig in PG&E's gas system with a PIR value of
31 100 feet or less falls under the DOT classification of gas distribution
32 pipe.

1 **d. Pipelines in Active Earthquake Fault Zones**

2 **(1) Earthquake Fault Automation Plan Overview**

3 PG&E recommends installing automatic control valves on
4 larger diameter, higher pressure transmission line segments
5 crossing active earthquake faults in urban areas when the segment
6 has a significant risk of rupture during a maximum magnitude
7 earthquake event. Northern California is an area of high seismic
8 activity. PG&E pipelines traverse 170 active earthquake fault
9 crossings, of which 46 are in Class 3, Class 4 or HCA areas.
10 These locations represent some of the largest location specific risks
11 to a pipeline. In addition, a major earthquake in an urban area
12 would severely strain emergency response resources, thus further
13 increasing the potential consequences from an earthquake induced
14 rupture. For the seismic crossing aspect of the project, PG&E
15 proposes to install valves within approximately one mile of each
16 side of the fault line. Pipeline segments that have already been
17 designed or reinforced to withstand the maximum projected fault
18 movement without rupturing were excluded from the ASV scope.
19 Because active earthquake faults are a location (point) specific risk,
20 pipeline fault crossings in Class 1 and 2 HCA areas (which are very
21 localized areas) were also included in the pipeline earthquake fault
22 crossing assessment, in addition to Class 3 and 4 areas.

23 PG&E will install automated pipeline isolation capability on all
24 pipeline earthquake fault crossings in Class 3 and 4 areas, and
25 Class 1 and 2 HCA areas where:

- 26
- 27 • The pipe has a PIR value of > 150 feet.
 - 28 • The earthquake faults are considered active.
 - 29 • The pipe has greater than a low threat of rupture under
30 maximum anticipated magnitude event conditions.

31 For pipelines crossing earthquake faults in sparsely populated
32 areas, a significant consequence of a pipeline rupture is loss of gas
33 service to downstream customers. The value of automated valves
in effectively addressing this consequence has to be evaluated on a

1 case-by-case basis. These crossings are included in PG&E's Gas
2 Transmission Pipeline Enhancement Program (discussed in more
3 detail below) and are not part of the Valve Automation Program.

4 **(2) Active Fault**

5 With the exception of a few rare examples, in tectonically active
6 regions, surface faulting occurs on existing faults that: (1) have
7 been the source of historical surface faulting; (2) are undergoing
8 active creep; or (3) have experienced surface faulting within the
9 past 11,000 years (Holocene). The Alquist-Priolo Earthquake Fault
10 Zone Act (Act) was established by the California Legislature in 1972
11 to mitigate the potential hazards of surface rupture associated with
12 seismic activity. The Act requires the California Geological Survey
13 to evaluate and delineate active faults throughout the state. A fault
14 or fault zone is considered active under the provisions of the Act if
15 there is evidence of surface displacement within Holocene time.
16 For evaluation of potential automated valve locations for pipe
17 segments crossing earthquake faults, active faults are defined as
18 those identified as "Historical" or "Holocene" in PG&E's Geographic
19 Information System (GIS) database, which includes the faults
20 meeting the criteria described in the first part of this paragraph.

21 **(3) Threat of Rupture**

22 The threat of rupture is determined by the potential magnitude
23 and likely frequency of a major earthquake event, and the
24 susceptibility of the pipe segment to rupture during a major event.
25 PG&E has developed a list of all transmission pipelines crossing
26 active earthquake faults. In this database, the earthquake fault slip
27 rate and the probability of a 6.7 or greater magnitude earthquake
28 occurring within the next 30 years are determined for each
29 segment. These two characteristics are typically related to one
30 another. For earthquake faults with a slip rate in the lowest
31 category of 0.2-1 millimeters per year, the corresponding probability
32 of a major event occurring is approximately two (2) percent over
33 30 years. PG&E has defined this category of earthquake fault as
34 being low threat. In those cases where PG&E has already

1 implemented design mitigation measures to prevent a rupture
2 based upon predicted magnitude earthquake events, these faults
3 are also deemed as low threat.

4 **(4) Gas Transmission Pipeline Enhancement Program**

5 After the 1989 Loma Prieta earthquake, PG&E performed a
6 system wide (Gas Supply and Gas Distribution Business Units)
7 earthquake vulnerabilities review. This was done to identify
8 opportunities to reduce earthquake vulnerability by mitigating the
9 potential weak points, such as pipeline earthquake fault crossings,
10 pipe supports for above ground piping and pipe spans, and
11 equipment in control rooms and stations. The studies found that
12 gas transmission pipelines and facilities are generally resistant to
13 earthquake damage and are expected to be operational following
14 earthquakes. This finding was consistent with previous experience
15 with modern gas pipeline systems struck by earthquakes in
16 California, such as Loma Prieta, Humboldt and Landers events,
17 and in other parts of the world, such as the Taiwan Ji Ji Earthquake
18 and Kobe Earthquake. The most significant vulnerabilities were
19 found at above-ground facilities involving anchorage and bracing
20 components at control rooms and stations, which have since had
21 these vulnerabilities mitigated. The remaining vulnerable locations
22 are fault crossings. Since buried pipelines are expected to perform
23 reasonably well in an earthquake event, they were not extensively
24 assessed during the original studies.

25 PG&E followed up the work that began after Loma Prieta with
26 the Gas Transmission Pipeline Enhancement Program, which
27 reviewed all gas transmission line fault crossings. Several fault
28 crossings have been replaced since 1994. Under this existing
29 program, PG&E reviews whether the risk of rupture due to an
30 earthquake can be mitigated by design, i.e., the pipeline segment
31 crossing the fault is re-designed to withstand the maximum
32 displacement expected from a fault rupture. This is a different and
33 complementary mitigative measure to installing automated valves.
34 In 2008, a list of all gas transmission pipeline fault crossings and a

1 multi-year plan of mitigations was developed and documented in
2 PG&E's RMP-04 "Ground Movement and Natural Forces Threat
3 Algorithm." There were a total of 170 fault crossings identified, 46
4 of which are in Class 3 or HCA areas. No crossings are in Class 4
5 areas. To date, 9 crossings in Class 3 areas, and 15 crossings in
6 total, have been mitigated by design. Of the remaining 37 fault
7 crossings in Class 3 or HCA areas, 17 are categorized as low
8 threat (i.e., have a PIR < 150 feet or have a low probability of
9 rupture), 16 will be automated with ASVs, and the other four (4) will
10 be fully mitigated by pipeline design. The ASV and pipeline design
11 mitigation work is planned to be completed by the end of 2014.
12 Examples of the types of design mitigation measures implemented
13 include: the use of thicker wall and more ductile pipe material, the
14 use of V-trench and light weight backfill to allow movement of the
15 pipe in an earthquake, the addition of geo-fabric wrap to reduce
16 friction between pipe and soil, and the realigning the pipeline so it
17 crosses the fault at a lower risk angle.

18 **3. Design Details of Pipe Segment Automation**

19 Once PG&E identified which segments of pipe will have automated
20 isolation capability, we then had to decide the optimal valve spacing
21 requirements for isolation, whether ASVs or RCVs will be used, define the
22 work scope required to provide complete isolation of a segment, and define
23 the specific design requirements for each site requiring modification.

24 **a. Valve Spacing Determination**

25 The valve spacing will affect the time it takes to evacuate gas from a
26 ruptured pipe segment after the isolation valves are closed. Valve
27 spacing will also affect the magnitude of the customer continuity of
28 service issues that will result from valve closures that take a pipeline
29 segment out of service.

30 49 CFR, Section 192.179(a), provides guidance for the installation
31 of isolation valves (i.e., sectionalizing block valves). Although this is not
32 applicable specifically to automated valves, it is a good starting point for
33 a maximum spacing guideline since it was developed taking into account

1 typical operational impacts of pipelines in various class locations. The
2 code requires:

3 (a) Each transmission line, other than offshore segments, must
4 have sectionalizing block valves spaced as follows, unless in a
5 particular case the Administrator finds that alternative spacing
6 would provide an equivalent level of safety:

7 (1) Each point on the pipeline in a Class 4 location must be within
8 2 1/2 miles (4 kilometers) of a valve.

9 (2) Each point on the pipeline in a Class 3 location must be within
10 4 miles (6.4 kilometers) of a valve.

11 (3) Each point on the pipeline in a Class 2 location must be within
12 7 1/2 miles (12 kilometers) of a valve.

13 (4) Each point on the pipeline in a Class 1 location must be within
14 10 miles (16 kilometers) of a valve.


15 To further evaluate maximum valve spacing impacts, PG&E hired a
16 pipeline engineering contractor to analyze the effects that various valve
17 spacings would have on the time to evacuate a pipe section after it had
18 been isolated for a full pipeline rupture event. The results found that if
19 the valve spacing was limited to the Class 3 requirement of eight miles,
20 the blowdown time has only minor impact on the overall time required to
21 isolate a pipe section using RCVs and minimal impact on facilitating
22 emergency response.

23 Eight mile spacing adds only approximately two minutes to the valve
24 blowdown time for a full line break situation, in comparison to five mile
25 spacing. A full line break with eight mile spacing with a pipeline starting
26 pressure of 1,000 psig is estimated to blowdown in five minutes. Based
27 upon this, an approximate maximum spacing of eight miles was used in
28 determining automated valve locations for Class 3 locations. As a
29 conservative measure, and to stay aligned with the code guidance, an
30 approximate five mile valve spacing was utilized for the higher impact
31 Class 4 areas. In either case, the maximum distance was allowed to be
32 slightly exceeded, to permit a valve to be automated in a more
33 accessible or lower public impact area.

34 Figure 4-7 illustrates the blowdown times for a full pipeline rupture
35 situation for a pipeline that is operating at 500 psig at the time of rupture.
36 It is important to note that this table is for a full line break situation; for a

1 partial line break or pipeline leak it would take much longer to evacuate
2 the gas, but the natural gas release rate and impact radius would be
3 much less as well.

FIGURE 4-7
PACIFIC GAS AND ELECTRIC COMPANY
BLOWDOWN TIMES VS. VALVE SPACING FOR FULL PIPELINE RUPTURES



4 The actual valve spacing PG&E chose for the Valve Automation
5 Program was often times less than the maximum valve spacing
6 guideline discussed previously, based upon the potential number and
7 criticality of customers that could lose service if a specific pipe segment
8 was taken out of service. As a general rule of thumb, valve spacing
9 distances were chosen that limited the potential number of customers
10 being fed off of a pipe segment to no more than 50,000.

11 In addition, where automatic valves are being recommended at
12 earthquake fault crossings, the spacing was reduced to more closely
13 bracket the threat. This closer spacing also minimizes the number of

1 customers within a fault crossing isolation segment, and any potential
2 loss of service to customers if an inadvertent valve closure occurs.

3 **b. RCV vs. ASV Usage Determination**

4 There are two types of automated valves that can be utilized for
5 isolation of pipe segments. RCVs are valves that can be closed via the
6 SCADA system by a remote operator located at a Gas Control Center.
7 ASVs are valves that are closed automatically based upon the local
8 control system at the valve site detecting a line rupture or any other
9 condition that the controls are programmed to trigger a valve closure.
10 PG&E analyzed the different risks and benefits associated with these
11 two systems to provide optimal automation for specific situations in
12 developing its Valve Automation Program.

13 **(1) Remote Controlled Valves**

14 RCVs rely upon the remote operator reviewing all available
15 data to determine if valve closure is warranted. By understanding
16 the current system conditions and configuration, and by being able
17 to evaluate the pressure and flow data at multiple sites, an operator
18 would be able to assess a multitude of factors into the decision to
19 isolate a section of pipeline by remotely closing valves. Valve
20 controls would be designed for the valve to fail in its last position if it
21 lost communication or power to limit the opportunity for a valve to
22 change position without human intervention. This makes it very
23 unlikely that an inadvertent or false valve closure will occur.

24 Because RCVs require human decision-making to close a
25 valve, they will not typically react as quickly to a rupture situation as
26 ASVs. PG&E anticipates that RCVs installed and utilized for full
27 line rupture isolation will typically allow for a pipe segment to be
28 isolated and blown down to near atmospheric pressure within
29 30 minutes, while an ASV would accomplish this in under
30 15 minutes if it identified a pipeline rupture condition. For an RCV
31 to be functional, it requires the gas SCADA system and
32 communication path to be operational. Because PG&E gas
33 SCADA communications typically use dedicated lease line or a
34 PG&E-owned microwave radio system, it is very likely they will be

1 available and operational after a major earthquake event, although
2 this is an operational risk of RCVs.

3 **(2) Automatic Shut-off Valves**

4 The greatest concern associated with ASVs is the risk of a false
5 or inadvertent closure of the valve. This is due to the fact that the
6 complexity of controls to accurately detect a rupture in a multi-mile
7 stretch of pipeline is challenging, especially in situations where
8 there are interconnected pipeline facilities. Because ASVs are
9 most often closed based upon low pressure or rate of rapid
10 pressure decline, the likelihood of a false closure is greatest when
11 system flow demands are the highest and at points closest to large
12 system loads where there would be less time to react to a false
13 closure. A false closure could create customer outages and
14 threaten PG&E's ability to maintain continuity of service to
15 customers.

16 ASVs require complex control systems. If the control systems
17 fail to function properly, there is the risk that the ASV controls will
18 fail to identify a pipeline rupture when one does occur, or that the
19 ASV controls could cause a cascade effect and isolate multiple
20 pipeline sections in addition to a section containing a pipeline
21 rupture. These concerns have been identified in industry studies
22 that reviewed the use of automatic controls to isolate a pipeline
23 segment.

24 Based upon the risks and benefits, PG&E plans to design
25 automated valves to be capable of both remote control and
26 automatic control, but to only initially enable the automatic control
27 capability for a small number of situations. The primary use of the
28 automatic control function would be where automated valves are
29 installed to isolate a pipeline segment at certain earthquake fault
30 crossings. At these locations, the valves would be installed in close
31 vicinity to the fault, thereby providing quicker and more reliable
32 pipeline rupture detection capability. PG&E would track and
33 evaluate the potential automatic control parameters, primarily
34 pressure and rate of pressure change, at RCV sites to further

1 evaluate the risk of a false closure and determine if expanded use
2 of automatic control is warranted in the future.

3 **(3) Continuity of Service Impact**

4 Since maintaining continuity of service to customers was a key
5 identified risk of using automatic controls, and in making the choice
6 between RCVs and ASVs, this section provides some additional
7 detail of the safety risks associated with a breakage in service
8 continuity. Restoration of gas service, depending on the scope of
9 an incident, may take several days or weeks. A loss of gas service
10 during the winter season may result in customers trying to relight
11 appliances themselves rather than waiting for qualified gas
12 personnel to safely restore service. Some customers have used
13 unsafe methods to heat their homes by using barbeques or
14 propane appliances, resulting in carbon monoxide poisoning.
15 Additionally, an interruption in service can pose health risks to sick,
16 elderly and disabled customers. A partial loss of pressure in a gas
17 distribution system due to loss of a transmission supply source may
18 result in a pressure drop, causing pilots on customer equipment to
19 extinguish. Subsequent repressurization of the system without
20 appropriate safety measures and procedures can result in the
21 potential of gas escaping into structures and posing a risk of
22 explosion.

23 **C. Scope of SCADA Enhancements**

24 If a pipeline leak or rupture occurs, there are several steps that determine
25 the overall response time to isolate and depressurize a pipeline segment. The
26 automation of pipeline isolation valves provides the capability for these valves to
27 be closed quickly once a determination has been made to isolate. Prior to
28 isolation, however, the leak or rupture has to be detected and the decision made
29 to isolate a pipeline segment. The SCADA enhancements described in this
30 section address these two steps. These enhancements fall into
31 three categories:

- 32 • Additional information relating to pressure, flows and other critical gas
33 system data within the SCADA system that will enhance controllers'
34 knowledge of gas system conditions and support early detection of, and

1 better understanding and pin pointing of, an excursion from anticipated
2 conditions.

- 3 • Additional training for operators in detection of events and proper response
4 to specific events.
- 5 • Advanced SCADA logic, tools and technologies that identify abnormalities
6 and bring them to the attention of the operator.

7 The Valve Automation Program includes the following Phase 1 actions as
8 part of each of these three categories of work.

9 **Additional enhancements to improve the information and tools used**
10 **for decision making:**

- 11 • Providing pressure measurement upstream and downstream of all
12 automated valves, and additional flow monitoring at key sites along the
13 automated pipeline sections. This would result in available pressure data at
14 approximately 5-8 mile spacing along the pipeline, and flow data at
15 approximately 15-20 mile spacing along the pipeline and at major cross-ties
16 to interconnected pipelines.
- 17 • Additional SCADA screens with detailed information regarding the pipeline
18 system including pressure, flow, rate of pressure and flow change, current
19 system configuration, connected major customers and loads, and key
20 system operational requirements.
- 21 • Additional information on manual valve positions with a specific focus on
22 valves affecting gas routing. This will likely be accomplished by a
23 combination of adding SCADA points for valve position of select manual
24 valves and providing an electronic “pin map” tool (SCADA screens that allow
25 for the manual input of the open or closed position of valves) for valve
26 positions not communicated via SCADA.
- 27 • Building advanced applications for the new data historian being
28 implemented in 2011 as part of an enterprise wide Information Technology
29 project and in conjunction with Control Room Management (CRM). These
30 advanced applications would integrate real-time data with other disparate
31 data and turn it into actionable information by gas operators.

- 1 • Integrating GIS and SCADA data historian providing Gas Operators with
2 access to physical pipeline information and geographical reference for
3 SCADA data points.

4 **Additional training enhancements:**

- 5 • Development of specific line rupture training exercises involving the use of
6 ASVs and RCVs using the training modeling software purchased by the
7 CRM initiative.
- 8 • Creation of specific job aids, pipeline shutdown plans and protocols to
9 facilitate identification of line breaks and provide direction to the operator on
10 proper response.

11 **Advanced SCADA tools and technology:**

- 12 • Advanced composite alarm logic and filtering that performs calculations
13 involving multi-site data to identify specific types of emergency action
14 situations.
- 15 • Evaluation and potential implementation of an on-line simulator that would
16 perform sophisticated transient flow simulation for the pipeline system to
17 alert the controller to potential abnormal or emergency operating conditions
18 on the pipeline, such as a large leak or partial line break, and notify the
19 operator.
- 20 • Evaluation and potential implementation of various detection technologies
21 connected to the SCADA system, such as leak, pipeline damage and ground
22 movement, that could provide proactive identification of developing risks.
- 23 • Evaluation of redundant communications between field valve automation
24 sites and the Gas Control Center, and the available communication
25 technologies available to accomplish this redundancy. PG&E's gas SCADA
26 system typical communication methods of dedicated lease lines and PG&E
27 owned RF MAS radio system are expected to have a very high level of
28 availability after an earthquake, but redundant communications would
29 provide backup assurance during an earthquake or for other circumstances
30 that could cause a potential single cause communications failure.

31 Many of these enhancements build off of the foundational work that is
32 currently in progress and funded by the 2011 Gas Transmission and

1 Storage (GT&S) Rate Case to comply with the requirements of 49 CFR 192.631,
2 Control Room Management. To confirm the appropriateness and direction of
3 these enhancements, optimize their implementation and identify additional
4 improvement opportunities, PG&E will instigate a comprehensive review of its
5 SCADA system and may adjust the above plans based upon the outcome of the
6 study. This review is further supported by the recommendations within the IRP
7 Report.

8 **D. Program Justification**

9 **1. Emergency Preparedness and Facilitation of Emergency** 10 **Response**

11 Installation of automated isolation capability on major pipelines in
12 heavily populated areas increases emergency preparedness, and may
13 reduce property damage and the danger to emergency personnel and the
14 public in the event of a pipeline rupture. Specifically, in the event of a
15 pipeline rupture the installation of automated valve isolation capability
16 provides for taking swift mitigative action, and:

- 17 • Can minimize property damage by eliminating the primary fuel source
18 for a pipeline rupture ignited fire in less time.
- 19 • Can minimize property damage and increase safety to emergency
20 responders and the public by: (1) allowing emergency response and
21 firefighting personnel to perform their actions unhindered by the high
22 heat intensity flame created by a high pressure natural gas fire; and
23 (2) allowing first responders to better plan their response by minimizing
24 the uncertainty of when the natural gas fuel source will be shut-off.
- 25 • Minimizes the quantity of natural gas released during a pipeline rupture,
26 reducing the environmental impact and containing the loss of product.

27 PG&E believes the expansion of RCV/ASVs is an important part of an
28 overall emergency response system and will help to restore public
29 confidence in the safety of natural gas pipeline systems. Following the
30 San Bruno accident, the Company reassessed the use of RCV/ASVs. We
31 conducted a domestic and international benchmarking study, and spent a
32 significant amount of time speaking with emergency response personnel.
33 This research led us to the conclusion that it would enhance public safety

1 and reduce property damage to install automated isolation capability on the
2 majority of its pipelines in heavily populated areas.

3 PG&E operates a significant mileage of large diameter, high-pressure
4 natural gas infrastructure in heavily populated areas of northern California.
5 Many of these pipelines are impacted by encroachment and urban growth
6 that has built up around lines, a good portion of which were installed over
7 50 years ago. In addition, the level of earthquake threat present in
8 California is high relative to most parts of the United States, as is the
9 potential for delayed emergency response to a pipeline rupture caused by
10 an earthquake event. There is a significant level of fire threat posed by
11 environmental factors in many heavily populated areas of northern California
12 and potential for a natural gas fire to be difficult to contain. In addition, the
13 northern California firefighting community has taken the stance that, in the
14 event of a pipeline rupture, a pipeline isolation and blowdown time of more
15 than 30 minutes would negatively impact emergency response and fire
16 containment efforts in response to a high-heat intensity natural gas ignited
17 fire. Automated valves facilitate firefighting emergency response efforts.
18 Finally, although it did not lead to specific legislation requiring the use of
19 automated valves in populated areas, the NTSB has stated that the lack of
20 automatic- or remote-operated valves has prevented companies from
21 promptly stopping the flow of gas to a failed pipeline segment, which
22 exacerbated damage to nearby property.^[5] This information provides
23 additional justification for installing automated valves within PG&E's gas
24 transmission system.

25 **2. The Pipeline Industry and NTSB Recommendations**

26 Pipeline industry studies have found that, unlike liquid petroleum
27 pipelines, a large portion of the damage associated with a natural gas
28 pipeline rupture occurs within a few seconds or minutes of the initial rupture
29 before the closure of automated valves would occur. The initial blast is
30 greater for a compressible natural gas pipeline, but escaping natural gas
31 being lighter than air will flow upward into the atmosphere. On the other

[5] NTSB Report on 1994 Texas Eastern Transmission Corporation (TETCO) New Jersey Pipeline Rupture.

1 hand, a liquid petroleum pipeline rupture will have less of an initial effect, but
2 liquids will flow out and away from the pipeline spreading fuel in a constantly
3 increasing affected area until isolated.

4 In its report to Congress, DOT summarized a study by the Southwest
5 Research Institute (SwRI) for the Gas Research Institute.^[6] The SwRI
6 study concluded that “almost no casualties would be prevented by the
7 installation of RCVs.” Of a total of 81 incidents studied from 1972 to 1997,
8 virtually all fatalities and injuries occurred at, or very near (within three
9 minutes), the time of initial rupture, long before the ruptured pipe section
10 would be isolated, even with RCVs installed.

11 Despite the inability of automated isolation valves to mitigate the
12 significant initial damage associated with a natural gas transmission pipeline
13 rupture, there have been identified benefits related to emergency response
14 and property damage mitigation that could be realized through the use of
15 automated isolation valves in situations where the natural gas release
16 ignites. In the same 1999 report to Congress, DOT identified that there is
17 evidence from the NTSB report on the 1994 TETCO 36-inch diameter
18 natural gas pipeline failure in Edison, New Jersey, that faster valve closure
19 may have allowed the fire department to enter the area sooner to extinguish
20 the fire, thereby potentially controlling the spread of the fires to adjacent
21 buildings. The DOT report concluded:

22 Automated isolation valves provide the capability for a section of pipe to
23 be isolated quickly upon confirmation of a rupture. Once the ruptured
24 section is isolated and no longer receiving additional gas, any fire would
25 subside as residual gas in the isolated section is burned. A fire would
26 be of greater intensity and would have greater potential for damaging
27 surrounding infrastructure if it is constantly replenished with gas. By
28 providing a definitive time when the line would be isolated following a
29 rupture, it is possible to identify when the fire would subside. This
30 knowledge can serve as a basis for risk assessment and response
31 planning, important considerations in certain heavily populated or
32 commercial areas, and an important factor in maintaining public
33 confidence.

34 While the DOT Office of Pipeline Safety has been noncommittal on
35 anything other than very limited use of automated valves, the NTSB has

[6] U.S. Department of Transportation, Research and Special Programs Administration, Remotely Controlled Valves on Interstate Natural Gas Pipelines (Feasibility Determination Mandated by the Accountable Pipeline Safety and Partnership Act of 1996, September 1999).

1 consistently recommended the use of automatic or remotely operated valves
2 on high-pressure pipelines in urban areas. A May 2000 United States
3 General Accounting Office report to Congress on Pipeline Safety, stated, the
4 “Safety Board has issued 11 recommendations since 1971 on using valves
5 to rapidly shut down the flow of product to a ruptured pipeline to mitigate
6 damage,” recommending automated valves usage be considered in urban
7 areas for high-pressure natural gas pipelines.

8 **3. Evaluation of Valve Automation Program by EN Engineering**

9 PG&E retained ENE to perform a review of the use of ASVs and RCVs
10 in PG&E’s proposed Valve Automation Program. ENE was chosen based
11 upon its extensive knowledge and breadth of expertise in gas transmission
12 system engineering, design, integrity management and code compliance. A
13 summary from its assessment of PG&E’s Valve Automation Program
14 follows. The full report is included as Attachment 4B.

15 ENE concluded that PG&E’s proposed Valve Automation Program
16 exceeds current pipeline industry regulations. Currently, there are no
17 prescriptive requirements in the prevailing pipeline code, Title 49 CFR
18 Part 192, that require operators to install automated valves. Subpart O
19 requires that operators perform a study of segments within an HCA to
20 determine if ASVs or RCVs would enhance pipeline safety in the HCA;
21 however, the rule does not contain an explicit mandate to install automated
22 valves. The state of California has adopted federal code with regard to
23 valves and valve spacing requirements.

24 ENE concurs with the Valve Automation Program’s focus on the
25 potential benefits to the public and emergency responders, particularly those
26 related to minimizing property damage, which can be achieved by a quick
27 isolation of the natural gas fuel source. ENE concludes that PG&E’s Valve
28 Automation Program will enhance public safety in areas with a long lead
29 time for emergency response or during catastrophic outside force events
30 such as earthquakes.

31 Once PG&E installs the automated valves, it is the opinion of ENE that
32 PG&E will have a valve automation program that leads the industry,
33 particularly in terms of formal selection criteria and quantity of automated
34 valves installed in high population areas. Based on the results of the

1 industry survey conducted by ENE, operators install automated valves
2 based upon their operating history and engineering judgment, but in general
3 their documented processes are not as defined and rigorous as the program
4 proposed by PG&E.

5 Based on the structured process for identifying line segments for valve
6 automation, ENE does not recommend any additional elements for inclusion
7 in the Valve Automation Program. The program proposed by PG&E as it
8 relates to automated valves is more conservative than prevailing pipeline
9 code and will enhance public safety in areas with a long lead time for
10 emergency response or during catastrophic outside force events such as
11 earthquakes. It is the opinion of ENE that the Commission should approve
12 the Valve Automation Program.

13 **E. Background on Industry Usage of Automated Valves**

14 PG&E's Valve Automation Program goes significantly beyond current code
15 requirements and typical past and current industry practices related to the use of
16 RCVs and ASVs. As part of developing the Valve Automation Program scope
17 and criteria, research was performed to understand current industry
18 perspectives and practices on the use of automated valves. The following
19 paragraphs document the current federal regulations on the use of automated
20 valves, and then summarize both domestic and international industry information
21 obtained regarding their usage.

22 **1. Federal Regulations**

23 Current state and federal regulations do not require automated isolation
24 capability for gas transmission pipelines. Title 49 CFR, Part 192, Subpart O
25 defines Gas Transmission Pipeline Integrity Management requirements.
26 Section 192.935(a) of Subpart O requires operators to conduct risk analyses
27 "of its pipeline to identify additional measures to protect the high
28 consequence area and enhance public safety." It further states, "Such
29 additional measures include, but are not limited to, installing Automatic
30 Shut-off Valves or Remote Control Valves..."

31 Section 192.935(c) further discusses the risk analysis requirements as
32 they relate to potential valve automation:

33 Automatic shut-off valves (ASV) or Remote control valves (RCV). If an
34 operator determines, based on a risk analysis, that an ASV or RCV

1 would be an efficient means of adding protection to a high consequence
2 area in the event of a gas release, an operator must install the ASV or
3 RCV. In making that determination, an operator must, at least, consider
4 the following factors--swiftness of leak detection and pipe shutdown
5 capabilities, the type of gas being transported, operating pressure, the
6 rate of potential release, pipeline profile, the potential for ignition, and
7 location of nearest response personnel.

8 The Office of Pipeline Safety within the DOT Pipeline and Hazardous
9 Materials Safety Administration has not issued any formal guidance as to
10 how to apply these requirements. Prior to the San Bruno accident, PG&E's
11 risk analyses pursuant to 49 CFR Section 192.935(c) led to a conclusion
12 that expansion of the use of automated valves beyond a case by case
13 assessment was not warranted.

14 **2. Domestic Natural Gas Transmission Industry Practice**

15 In an effort to gauge the industry perspective on the use of Automated
16 Line Isolation Valves ("automated valves", includes both ASVs and RCVs) to
17 respond to line breaks in the gas transmission industry, PG&E contracted
18 with ENE to perform an industry survey. Survey responses were obtained
19 from a dozen companies (including PG&E) involved in interstate and
20 intrastate gas transmission. Responding companies operate a total of
21 68,000 miles of transmission pipeline (about 23 percent of the U.S. gas
22 transmission pipeline system) with individual companies operating as few as
23 200 miles to as many as 25,000 miles. The following findings are based
24 upon the survey results.

25 All but two of the respondents, slightly over 80 percent, use some
26 automated valves to be able to isolate pipe segments in the event of a line
27 break. While the majority of respondents had some usage of automated
28 valves in the event of a line break, usage levels varied greatly, and many
29 times their installation was based upon regulatory and permitting concerns
30 and requirements rather than from formal risk assessments. In general,
31 there is a strong preference of survey respondents to utilize RCVs over
32 ASVs for automated isolation. While ASVs have the advantage of more
33 rapid response, it is clear that inadvertent closures make the choice less
34 desirable.

35 The subparagraphs below provide additional detail on the survey
36 results.

1 **a. Industry Perspective on Automated Valves**

2 The following is a summary of responses for questions specific to
3 Automated Valves:

- 4 • Three companies (33 percent of those providing a response)
5 indicated there is a standard applied when installing automated
6 valves.
- 7 • The greatest single factor considered when installing an automated
8 valve is population, which drives class location and HCAs. The next
9 most mentioned factors were operational concerns and the time to
10 isolate a pipe segment.
- 11 • Similarly, the greatest single factor under which an operator may
12 evaluate automating an existing valve would be the change of
13 population density around an existing line.
- 14 • With the exception of recent pipeline projects subject to special
15 permits, formal documented studies are not completed regarding
16 installation of automated valves on new pipelines.
- 17 • The primary consideration to determine automated valve spacing is
18 49 CFR Part 192 maximum valve spacing requirements.
- 19 • When considering ASV or RCV, the preference is to use RCV
20 because it requires human intervention to reduce the likelihood of
21 inadvertent valve closure.

22 **b. Industry Perspective on Automatic Shut-Off Valves**

23 Six companies, 55 percent of the respondents, have some
24 automatic shut-off valves installed in their pipeline system. Listed below
25 is a summary of responses for questions specific to automatic shut-off
26 valves:

- 27 • Over 85 percent of operators with automatic shut-off valves have
28 experienced a false valve closure.
- 29 • Unusual operating conditions, freezing of the signal line, and
30 instrumentation failures, were stated as factors causing false closure
31 of ASVs.

- Operator efforts to minimize false valve closure included disabling of the ASV controls, modifying the ASV setpoints, and converting the valves to RCVs.

c. Industry Perspective on Remote Controlled Valves

The survey also addressed the use of RCVs for line rupture control rather than other purposes. Eight companies, approximately 75 percent of the respondents, have some remote control valves installed in their pipeline system for line break purposes. Listed below is a summary of responses for questions specific to remote controlled valves:

- When using RCVs all respondents use the valves for the dual purpose of operation control and rupture/line break control.
- Only one company identified an incident which occurred causing the valve to close inadvertently; two companies indicated an incident where the valve failed to close when commanded.
- Operators view the primary advantage of RCV to be the human evaluation of the condition of the pipeline before closure. The primary disadvantage is the potential interruption of power or communication with the valve controller.
- Most operators do not use any line break detection software. Operators monitor pressure, flow, and rate of change alarms to identify line breaks.
- Respondents were split on the existence of a formal procedure to recognize and confirm a line break prior to closing a valve.
- Pipeline operators rely upon operator qualification and written procedures to maintain the readiness of staff to recognize and respond appropriately in the event of a failure.

3. International Natural Gas Transmission Industry Practice

PG&E contracted with Energy Experts International to gather information from natural gas pipeline operators and utilities in Japan, France, Germany, Netherlands, Spain and the United Kingdom regarding their use of automated isolation valves for gas transmission systems. The companies contacted operate a total of approximately 50,000 miles of gas

1 transmission pipeline. The specific results varied, but several common
2 themes were:

- 3 • All contacted companies reported usage of RCVs for automated
4 isolation of pipeline segments, particularly in heavily populated areas, in
5 the event of a line rupture. For each of these companies, a systematic
6 program was in place which defines when RCVs are installed.
- 7 • There was a strong preference for remotely operated valves over
8 automatic shutdown valves. Only one European company had
9 automatic line rupture controls in operation, and these are being
10 converted to remotely controlled valves due to concerns regarding the
11 triggering mechanism not being reliable and false closures.
- 12 • RCV installations were typically installed at 5-10 mile spacing. RCVs
13 were ball valves using a variety of actuator types.
- 14 • No problems were reported with the use of RCVs.

15 Japan had the most sophisticated system with RCVs utilized by the
16 three largest utilities throughout their transmission networks, nearly all of
17 which run through very heavily populated areas (a high percentage of which
18 is Class 4). Since gas is produced from Liquefied Natural Gas (LNG)
19 located near the population centers, there are no long cross-country
20 transmission pipelines in Japan. Ground movement sensors that are
21 installed at the district regulator station entry points into their gas distribution
22 networks are used in Japan.

23 **F. Project Phases**

24 In order to effectively manage resources and capital expenditures, PG&E
25 will implement the Valve Automation Program in two phases, with the second
26 phase composed of an “A” and a “B” component. A map showing the locations
27 prioritized for Phase 1, 2A, and 2B implementation is provided as
28 Attachment 4A. In this Implementation Plan, PG&E is only seeking cost
29 recovery for Phase 1.

30 **1. Pipe Segment Phase Prioritization**

31 Determination of phase priorities was aligned with the two primary
32 factors in segment selection: population density and PIR. The following

1 table shows the various miles of PG&E gas transmission pipeline by Class,
 2 HCA and PIR value, and highlights the focus of Phases 1, 2A and 2B.

**TABLE 4-3
 PACIFIC GAS AND ELECTRIC COMPANY
 PIPE MILES BY PIR, CLASS AND HCA**

Line No.	PIR	HCA Class 3&4	Non-HCA Class 3&4	Class 3&4 Miles	HCA Class 1&2	Non-HCA Class 1&2	Total Miles
1	501+	132(a)	23(c)	155	56	1,806	2,016
2	301-500	208(a)	68(c)	277	10	394	680
3	251-300	98(b)	41(c)	139	3	289	431
4	201-250	133(b)	71(c)	204	4	313	521
5	151-200	153(b)	128	281	4	284	569
6	101-150	161	268	430	3	453	886
7	0-100	60	179	239	1	418	658
8	Totals	947	778	1,715	80	3,958	5,763

- (a) Focus of Phase 1.
- (b) Focus of Phase 2A.
- (c) Focus of Phase 2B. Phase 2B also includes unsustained pipe lengths of Phase 1 & 2A segments.

Note: The pipe mileage table is based upon a January 3, 2011 GIS database snapshot for all DOT gas transmission designated pipe not including Gas Gathering. All mileage statistics for the Valve Automation Program and pipe segment analysis are based upon this data snapshot.

3 **2. Description of Phase 1 Program (2011-2014)**

4 Phase 1 will provide automated isolation capability for 276 miles of pipe
 5 in Class 3 HCA locations with a PIR > 300 feet and Class 4 locations with a
 6 PIR > 100 feet. To automate these pipe segments, an additional 246 miles
 7 of adjoining segments are required to be automated, of which 125 miles
 8 otherwise would have been automated in Phase 2. Phase 1 work results in
 9 a total of 522 miles of pipeline with automated isolation capability. It also
 10 includes automatic controls for pipelines crossing 16 active earthquake
 11 faults.

12 Phase 1, which contains work at 80 specific valve sites, is planned to
 13 provide automated isolation capability for 185 valves, and is planned to
 14 upgrade the controls for 43 valves that currently have some remote control
 15 capability. As part of this effort, at least 50 new valves will be required to
 16 allow for this automation. Additionally, PG&E will install 30 new flow meters
 17 to provide necessary flow information to facilitate decision making on when

1 to isolate a pipe segment. The following two tables provide additional details
 2 on the specific valve automation work by year and geographical area:

**TABLE 4-4
 PACIFIC GAS AND ELECTRIC COMPANY
 VALVES AUTOMATED BY AREA IN PHASE 1 (2011-2014)**

Line No.	Geographical Area	Existing Valves to be Automated	Replaced or New Valves Automated	Existing Automated Valves to be Upgraded	Total Valves Automated in Phase 1
1	Peninsula (2011 Construction)	12	8	9	29
2	Peninsula (2012 Construction)	12	17	10	39
3	San Jose	13	2	6	21
4	Antioch to Richmond	27	7	3	37
5	Oakland to Fremont to Livermore	20	4	2	26
6	Brentwood Area	3	5	5	13
7	Sacramento Area	6	5	1	12
8	Vallejo-Fairfield Area	15	2	0	17
9	Stockton-Modesto Area	17	0	1	18
10	Bakersfield Area	5	0	2	7
11	Eureka Area	3	0	2	5
12	Barstow Area	2	0	2	4
13	Total	135	50	43	228

Note: Based upon preliminary analysis of existing valve installation conditions.

3 Phase 1 includes line segments that meet either of the following criteria:

- 4 • Sustained length of HCA pipe within a Class 3 location with a PIR of
 5 three hundred feet (300') or greater.
- 6 • Class 4 with a PIR of one hundred feet (100') or greater.

7 For identifying a sustained length, a section of pipeline had to contain at
 8 least five (5) miles of HCA and the HCA pipe had to be over 50 percent of
 9 the pipe length between existing isolation valves. Non-sustained lengths
 10 were deferred to Phase 2. Based upon PG&E's pipeline system footages,
 11 approximately 80 percent of Class 3 pipeline segments with a PIR of over
 12 300 feet are also HCAs, and just over 80 percent of these pipe segments
 13 have sustained lengths of HCAs.

14 Additionally, some segments not meeting the Phase 1 criteria were
 15 included in the Phase 1 implementation due to efficiencies gained by making
 16 the work part of Phase 1. This typically occurred where segments were
 17 contiguous to Phase 1 segments or when valve automation work that would


1 have been part of Phase 2 segments is required within stations where
2 Phase 1 work is planned.

3 Phase 1 also includes valve automation for unmitigated pipeline
4 segments crossing active earthquake faults that met the following criteria:

- 5 • The earthquake fault was identified as having a greater than
6 two (2) percent probability of having a 6.7 or greater magnitude
7 earthquake event within the next 30 years.
- 8 • The segment is in a Class 3, Class 4 or Class 1 or 2 HCA location and
9 the line segment had a PIR of one hundred fifty feet (150') or greater.

10 The vast majority of mileage within Phase 1 is based upon the Class 3
11 HCA, PIR > 300 feet, criteria. This classification of pipe is highlighted in the
12 following map for the portion of PG&E's service territory from north of Chico
13 to south of Fresno. There are only small portions of HCA, PIR > 300 feet
14 pipe outside of this map in the Burney, Bakersfield and Barstow areas.

**FIGURE 4-8
PACIFIC GAS AND ELECTRIC COMPANY
CLASS 3 HCA PIPE WITH PIR > 300 FEET**



1 Figure 4-8 shows that the overwhelming majority of Phase 1 projects will
2 take place in the greater San Francisco Bay Area due to the population
3 density of this region.

4 A subset of Phase 1 work was chosen for implementation in 2011 to
5 “launch” the program. The launch work will focus on sites within the
6 San Francisco Peninsula between Milpitas and San Francisco and will allow
7 us to identify standardized processes and designs that should be used for
8 program implementation, to gain experience in the types of issues that will
9 be faced for various installation scenarios, and to better understand cost and
10 schedule components of program execution.

3. Description of Phase 2A

Phase 2A includes line segments that met all of the Phase 1 Class 3 HCA criteria except for PIR value. Whereas Phase 1 focused on segments with a PIR over 300 feet, Phase 2A includes those sustained length line segments with a PIR value between 150 feet and 300 feet. Phase 2A consists of installing automated isolation capability on approximately 535 miles of gas transmission line, of which 345 miles are in Class 3 locations. This work will require the automation of roughly 130 valves.

4. Description of Phase 2B

The Phase 2B implementation includes the remainder of the in-scope Class 3 locations. This includes the remainder of Class 3 line segments with a PIR greater than 200 feet that were not included in Phases 1 and 2A. It primarily consists of scattered short segments of Class 3 pipe on longer lengths of pipeline traversing predominantly Class 1 and 2 areas. Phase 2B consists of installing automated isolation capability on approximately 725 miles of gas transmission line, of which 235 miles are in Class 3 locations. This work will require the automation of roughly 200 valves.

G. Specific Projects Scope Determination

1. Phase 1 Valve Automation

a. Determination of Specific Automation Segments

Before estimating valve automation project costs, the specific project scope for each Phase 1 project was determined. An estimating team of ENE engineers, working in conjunction with PG&E project and planning engineers, and utilizing the defined Phase 1 scope of segments to automate, first determined the start and end points for each automation segment. This was done utilizing information obtained from system operating maps, station operating diagrams, GIS data, and current SCADA information. This information was combined with PG&E knowledge of customers connected to various segments, to determine valve spacing and specific start and end points.

Where feasible while still maintaining desired valve spacing, valve sites that are already automated were selected. These valves may have been automated for other purposes than for pipe segment isolation, but

1 can easily be equipped with this functionality. Automation of an existing
2 valve was the next most attractive option. Installation of a new mainline
3 valve or construction of a large multi-valve vault was generally the least
4 attractive option. In most cases start and end points were aligned with
5 existing valve locations.

6 **b. Determination of Pipe Segment Automation Requirements**

7 The team next determined automation requirements for each pipe
8 segment using the same information discussed above plus construction
9 documents for existing sites. This determined the full scope of
10 automation work required for Phase 1. Providing automated isolation of
11 a pipeline segment is not as simple as automating a mainline block
12 valve at either end of the pipeline segment. For each pipe segment to
13 be equipped with automated isolation capability, it is required to assess
14 all potential points where gas could enter the segment. This includes
15 not only the start and end points of the mainline segment, but also all
16 taps off the pipeline within the segment. For each point, a determination
17 is needed as to the type of equipment and controls required to most
18 effectively and efficiently isolate the segment. The following highlights
19 some of the assessments that are required:

- 20 • Taps connecting the pipeline segment to another gas transmission
21 pipeline (cross-tie connection). An assessment is required to
22 determine if valves in this cross-tie piping need to be automated or if
23 the cross-tie valves can be kept in the closed position and only
24 opened when required to address an abnormal operating condition.
- 25 • Taps that supply gas to smaller diameter transmission or distribution
26 feeder main systems without any reduction in pressure. An
27 assessment is required to determine if the tap valves should be
28 automated or check valves added at the tap location to prevent
29 backflow into the isolated pipe segment and to minimize the extent
30 of the isolated piping. Particular attention needs to be paid to gas
31 systems downstream of tap valves that can be supplied from other
32 gas systems with an objective of minimizing the potential customer
33 outages due to isolation of the pipe segment.

- 1 • Taps that supply gas to regulator stations, which then serve lower
2 pressure gas systems. If the stations have pilot-operated regulator
3 valves, the regulator valve controls can be easily modified to prevent
4 backflow through the regulator station and into the isolated segment.
5 For taps supplying gas to larger regulator stations with
6 controller-operated regulator equipment, check valves can be
7 installed in the tap line to prevent flow of gas backwards through the
8 regulator station.
- 9 • Taps on either side of mainline valves that are connected together
10 (i.e., bridle valves) at the start and end of each segment require
11 special attention to ensure gas cannot bypass around the mainline
12 valve into the isolated pipe segment. An assessment is required to
13 determine if one of the bridle valves can be kept in the closed
14 position during normal operations, or if the bridle valves require
15 automation or check valves installed to prevent gas bypassing
16 around the mainline valve.

17 For the Phase 1 projects, initial assessments have been made as
18 part of the feasibility and preliminary scoping process; further review and
19 confirmation will be made during the later stages of the engineering
20 process.

21 **c. Determination of Specific Projects**

22 The work scope was then broken into distinct projects. Projects
23 consist of all work scope items related to a specific location. A single
24 project location often included portions of work for multiple Phase 1 pipe
25 segments for those cases where a specific location had multiple
26 incoming and outgoing pipelines associated with it. For each project
27 location, the station was then reviewed for any additional work scope
28 that would have been associated with Phase 2 work scope at that site,
29 but should be moved into Phase 1 for efficiency purposes. In each
30 specific project, PG&E also included any minor tap work associated with
31 the upstream pipeline segments up to the next project location.

1 **d. Determination of Specific Project Design Requirements**

2 After segregating the work into specific projects, design
3 requirements for each project had to be created. These design
4 requirements then formed the scope basis for the project cost estimates.
5 The design requirements assessment work generated details related to:

- 6 • Existing valves with automation that require additional controls for
7 use in isolation of pipe segments.
- 8 • Existing manual valves that require valve actuators and automation
9 control packages. Figure 4-9 depicts manual valves that are
10 installed in a vault, and Figure 4-10 depicts a buried valve with
11 manual gearing installed above ground. These are two examples of
12 types of existing valves that could be automated.

**FIGURE 4-9
PACIFIC GAS AND ELECTRIC COMPANY
MANUAL VALVES INSTALLED IN A VAULT**



**FIGURE 4-10
PACIFIC GAS AND ELECTRIC COMPANY
BURIED VALVE WITH MANUAL GEARING INSTALLED ABOVE GROUND**



- 1
- 2
- 3
- Existing manual valves that require replacement or relocation and then automation. The following photos depict manual valves that would need to be replaced prior to automation.

**FIGURE 4-11
PACIFIC GAS AND ELECTRIC COMPANY
EXISTING MANUAL VALVES REQUIRING REPLACEMENT**



- 4
- 5
- 6
- 7
- 8
- 9
- New automated valves and new check valves that need to be installed.
 - Instrumentation, metering, pressure monitoring and controls required as part of valve automation at each site.
 - New SCADA installations or upgrade requirements at each site, including power and telecommunications requirements.

- 1 • Existing regulator stations that need controls modifications.
- 2 • Piping modification requirements at each site.
- 3 • Site improvement requirements including vault installations, fencing,
- 4 paving, and land acquisition and permitting.

FIGURE 4-12
PACIFIC GAS AND ELECTRIC COMPANY
EXAMPLE OF SITE IMPROVEMENTS



5 All valves being automated as part of the Valve Automation Program
6 are installed beneath the ground surface. The valve actuator equipment
7 that is required for an automated valve to be operated can be installed
8 directly on top of the valve or on top of a “valve extension” that extends
9 the valve shaft upwards to allow the valve actuator to be located
10 aboveground for a buried valve. The valve actuator needs to be
11 accessible for maintenance, so it cannot be buried. For situations where
12 the valve shaft cannot be extended aboveground, such as for valves
13 buried beneath streets or sidewalks, a vault needs to be installed around
14 the valve to allow the valve actuator to be mounted directly on top of the
15 valve and for it to be accessible to maintenance personnel.

16 To determine whether or not an existing valve requiring automation
17 should be automated or if the existing valve must first be replaced or
18 relocated, the following information must be gathered:

- 1 • If a pipeline mainline isolation valve, does the existing valve allow
2 for In-Line Inspection (ILI) of the pipeline?
- 3 • Does the valve type allow for automation?
- 4 • Does the valve condition provide for reliable automation?
- 5 • Does the valve installation configuration allow for automation?

6 Mainline valves that do not allow for ILI, such as gate valves, plug
7 valves and reduced port ball valves need to be replaced, as do floating
8 ball valves due to age of these valves and high torque requirements.
9 Also, valves that do not fully shut-off flow between two pipe segments
10 and valves that are hard to turn will be replaced if they cannot be
11 repaired through maintenance. These valves were assumed to be
12 repairable for this initial assessment, but will be further evaluated during
13 subsequent engineering. Additionally, valves that are buried in a
14 configuration or location that does not allow for their automation will be
15 replaced.

16 Locations requiring vault installations represented a particular
17 challenge, and the design requirements for these locations assumed
18 vaults could be installed around the valves but also assumed some
19 relocation work would be required to PG&E lines or facilities of third
20 parties to provide for the vault installations. Specific design
21 requirements for these locations will be solidified in the detailed
22 engineering phase of work.

23 For any sites requiring mainline valve automation, the mainline
24 valve, any bridle taps and related piping will be upgraded to allow for
25 future inline inspection of the pipeline.

26 **2. Phase 1 Metering**

27 Work scope for Phase 1 metering projects was determined by utilizing
28 the list of pipelines to be equipped with automated isolation capability in the
29 first phase of valve automation. Each of these pipelines was evaluated to
30 determine where additional metering would be beneficial to facilitate gas
31 control operator decision making related to line rupture events. A general
32 rule of thumb of every 15-20 miles was utilized as a starting point based
33 upon input from PG&E's Gas Control Operations Engineering group. As

1 controllers gain operating experience with the new meter data, an
2 assessment will be done to validate the rule of thumb and to determine
3 whether additional metering is required. Due to the limited number of
4 meters to be installed (thirty new meters) these meters were lumped into a
5 single Phase 1 metering project.

6 **H. Program Changes Based on CPUC Workshops and Feedback**

7 PG&E supports efforts to enhance coordination and communication between
8 the Implementation Plan program management team and the Commission and
9 other intervenors regarding proposed Valve Automation Plans. At the CPUC
10 Gas Implementation Plan Workshop held on June 22 and 23, 2011, and in
11 subsequent discussions, PG&E received valuable information and feedback
12 regarding areas for improvement of the proposed program and approach.

13 Specifically, PG&E received feedback that all Class 4 locations should be
14 considered for automation in Phase 1, not just those Class 4 locations with a
15 PIR > 100 feet. This change would have no effect on pipe segments identified
16 for automation because PG&E currently has no gas transmission pipe as
17 defined by DOT in a Class 4 area with a PIR < 100 feet. However, any pipe that
18 may fall into this category in the future would likely have physical characteristics
19 that would make it prone to leak rather than rupture and installation
20 characteristics more similar to gas distribution networked pipe systems that
21 would make segment isolation difficult. Any pipe in this category would also
22 pose less firefighting issues due to the smaller impact radius. Therefore,
23 PG&E's valve automation program and approach described in this chapter was
24 not adjusted based on this feedback.

25 **I. Project Cost Estimating Methodology**

26 **1. General**

27 PG&E retained ENE to estimate costs for Phase 1 of the Valve
28 Automation Program. The accuracy of the estimates of capital expenditures
29 were Class 4 level estimates (-30% to +50%) as defined in the Association
30 for the Advancement of Cost Engineering International Recommended
31 Practice No. 18R-97.

32 ENE has significant expertise in transmission pipeline design and
33 distribution system designs including metering and regulating stations,

1 compression, gas conditioning, valve automation and controls, electrical,
2 metallurgy, and pipeline integrity. ENE relied upon project costs from work
3 completed for other natural gas utilities for similar valve replacement
4 projects and similar facility revisions, the knowledge and experience of ENE
5 in-house staff, and pricing from subcontractors, material manufacturers,
6 suppliers, and consultants.

7 PG&E provided input to the cost estimating process, sharing knowledge
8 on known specific site issues that potentially could have a cost impact,
9 PG&E design and construction standards, PG&E project overhead rates,
10 and contract construction prevailing wage labor rates.

11 **2. Project Estimating Approach**

12 Cost estimates were generated using the list of specific project work
13 scope items and a unit cost database for materials and labor costs
14 associated with each specific work scope item. The level of project
15 definition was less than 15 percent at the time of the estimate's
16 development.

17 Protocols to determine the work effort per site were established to
18 ensure consistent estimates across the system. In addition to the specific
19 project work scopes, other considerations in the development of the
20 individual estimates included site congestion, site complexity and difficulty in
21 providing electrical power to the site.

22 **3. Unit Cost Approach**

23 ENE identified unit costs for various materials, construction labor, and
24 engineering tasks associated with each potential scope of work. These
25 base units were then combined to develop cost estimates for each valve
26 automation project. Material unit costs were developed for valves,
27 actuators, pipe, fittings, valve actuation instrumentation, valve control
28 equipment, SCADA hardware (including pressure transmitters), and fencing
29 and gravel. Unit costs were established for various sizes of materials where
30 applicable. Construction unit costs were developed for valve automation
31 installation, valve automation upgrade, valve installation, site restoration,
32 extended controls trenching, stopple fitting installation, bypass installation,
33 telecommunications, Remote Terminal Unit (RTU) installation, vault

1 installation, clearance execution, land and permitting, electrical power
2 connection and district regulator station modifications. Engineering unit
3 costs were developed for design engineering, SCADA programming, and
4 mapping and records. Unit costs were established for various levels of
5 complexity for construction and engineering tasks.

6 The type of valve automation work at each site fell into one or more of
7 the following categories which could then be utilized for comparison of
8 estimates between projects:

- 9 • Automate an existing valve.
- 10 • Replacement of an existing valve to include automation.
- 11 • Installation of a new valve (with automation).
- 12 • Upgrade of existing automated valve hardware.
- 13 • Automation or replacement of existing valve in vault.

14 Once a few specific project scopes were created, these unit costs were
15 applied and the results compared against expected costs for a project of this
16 magnitude. This served as a quality control check.

17 **4. Description of Typical Valve Automation Types and Associated** 18 **Costs**

19 The scope of work for each type of automation will vary in terms of both
20 material and labor costs. Assumptions for each type are described below.

21 **a. Automation of an Existing Valve**

22 The estimates reflect the costs associated with the automation of an
23 existing valve. Scope includes the material and labor needed for
24 mounting a new actuator, excavating and installing upstream and
25 downstream sensing lines, conduit, power supply, SCADA work, and
26 any additional items required to complete the retrofit including backfill
27 and permanent restoration.

28 **b. Replacement of Existing Valve at Same Location**

29 The work scope for projects where the existing valve requires
30 replacement includes both removal of an existing valve and the
31 installation of an automated valve assembly. This included any piping

1 work required to make the pipe section including the valve assembly
2 capable of ILI.

3 Areas found to have excessive constructability issues including
4 substantial impact to the public were noted. In some cases, it was
5 determined that it was more feasible to abandon the existing valve
6 location and relocate a new valve assembly to a new site. Removal and
7 restoration costs were included for the retired facilities.

8 **c. Installation of New Valve**

9 For the purpose of these cost estimates, a new valve installation
10 refers to installation of a new main line valve not previously in service
11 along the pipeline system. Thus, additional costs associated with the
12 construction of a new site, such as permitting and land acquisition,
13 fencing or other standard security measures, electrical systems and
14 telecommunications were included in the estimates.

15 **d. Upgrade of Existing Automated Valve**

16 In cases where the existing valve is already automated, existing
17 hardware and/or software will be upgraded to comply with the design
18 and operational standards created by this program. Therefore, costs for
19 engineering, materials, and labor were incorporated.

20 **e. Automation or Replacement of Existing Valve in Vault**

21 Under certain circumstances, automating valves at the selected site
22 may require installation of a large vault(s) installed below ground under
23 roadway pavement. For these cases, the following additional costs
24 were included in addition to the cost to automate, replace, or install the
25 valve(s):

- 26 • Costs—both material and labor—associated with the installation of
27 the vault(s) required for valve automations.
- 28 • Electric actuators were assumed for all vault applications.
- 29 • Costs to resolve conflicts created by vault installations with any
30 nearby underground facilities and other utilities.
- 31 • Roadway pavement restoration costs.

1 Excavation and restoration costs are recognized to be substantial
2 for projects of this type.

3 **5. Cost Basis Assumptions**

4 **a. Economic Assumptions**

5 An average labor productivity rate was utilized, which assumed the
6 project will progress at a typical rate and is based upon a normal project
7 schedule duration of this type. No special considerations for extreme
8 weather conditions or for obstacles not typical of Right-of-Way (ROW)
9 construction were included in this estimate.

10 It was assumed that pipelines will be taken out of service for valve
11 replacement/installation where required, and no special provisions were
12 considered to maintain system flows unless noted. However, typical
13 clearance costs were factored by location into the estimates.

14 Unit cost estimates were based in 2011 dollars. After determining
15 an overall project schedule, an escalation factor of 3.12 percent per year
16 was applied for projects after 2011.

17 **b. Exclusions**

18 The estimates do not include costs for unforeseen items that require
19 specialized equipment or labor, or require specialized permits. No
20 unique construction costs outside of those specified in the unit cost
21 definitions were included. Potential costs to comply with atypical permit
22 constraints or for handling site specific soil contamination beyond
23 minimal levels were also not included. It was assumed that pipelines
24 are in existing ROWs and that only the cost of modifications to existing
25 easements will be required for any new above ground facilities.

26 It is assumed that the valve assembly will be cathodically protected
27 with the pipeline; therefore, no significant cost for a corrosion protection
28 system was included in the cost estimate. Also, the cost of any pipeline
29 gas that is required to be purged (i.e., blown down) to atmosphere to
30 allow for piping or valve replacement work to occur was not included in
31 the cost estimates.

1 **6. Direct Cost**

2 Direct costs considered in these estimates include materials,
3 construction labor, and engineering.

4 **a. Material**

5 The unit pricing for materials largely consists of quotes obtained
6 between the fourth quarter of 2010 and first quarter of 2011. Adjustment
7 to material pricing would be required if there is a substantial change in
8 market conditions.

9 **(1) Valves**

10 The estimates were based on ball valves with the following
11 characteristics: trunnion mounted, weld ends, full bore, American
12 National Standards Institute rated to meet MAOP, and supplied with
13 a valve extension and coated for buried service.

14 **(2) Pipe and Fittings**

15 Cost estimates were based on standard schedule 40,
16 grade X-52, API 5L pipe coated with fusion bonded epoxy. Lengths
17 and specifications to meet minimum 49 CFR Part 192 requirements
18 for fabricated assemblies were also assumed. Fittings of
19 commensurate size and grade were also assumed.

20 **(3) Actuators**

21 The cost estimates included the necessary actuator
22 components to automatically operate a ball valve. Two different
23 actuator types were used to generate the costs estimates:

24 (1) Low pressure gas powered double acting piston actuator for
25 aboveground applications.

26 (2) Direct Current motor driven electric actuator for vault
27 applications.

28 **(4) SCADA**

29 Cost estimates include the materials needed to provide
30 communications between the automated valves and the gas
31 SCADA system.

1 **b. Construction Labor**

2 For purposes of this cost estimate methodology, the general
3 category “construction labor” was used to account for both contract and
4 company labor required to complete valve automation tasks outlined in
5 the individual project work scopes.

6 **(1) Pipeline Contractors**

7 Unit pricing for contractor labor was derived using a prevailing
8 wage for pipeline station work in the state of California of \$120 per
9 manhour, which was supplied by PG&E and based upon current
10 contract rates for controls construction. The number of associated
11 hours and crew size was tailored to the scope of work needed per
12 location. Unit hours to complete identified tasks associated with
13 valve assembly installation or retrofit are based on historical data.

14 Project duration of twenty-five (25), 10-hour days were
15 assumed for valve installation and replacement projects. Valve
16 automation or upgrade of existing automation projects utilized a
17 ten (10) day (ten hour day) duration. Crew sizes were scaled in
18 accordance with diameter of the valve in question.

19 Work items include pipe, fittings and valve installations,
20 instrumentation and controls installation, hydrostatic testing, x-ray,
21 excavation and backfill, work associated with installations such as
22 concrete pads or pipe supports, and construction inspection.

23 **(2) Restoration**

24 Site restoration costs for valve replacement or installation were
25 assumed to be more significant than those for automation or
26 upgrade to existing automation project. However, in both cases,
27 some restoration work will be necessary due to anticipated
28 trenching for control lines and electrical conduit.

29 **(3) Vaults**

30 Estimated costs associated with the installation or relocation of
31 a vault, or the abandonment of a buried vault structure, were
32 included in the construction labor category for the purpose of this
33 high-level estimate. Material for the vault installation, as well as
34 backfill and materials for site restoration, were included in this unit

1 cost. Also included were typical costs to address any conflicts
2 created by the vault installation such as interferences with other
3 buried pipes and structures.

4 **(4) Clearance Cost**

5 Costs associated with gas continuity planning and coordination
6 such as LNG/Compressed Natural Gas (CNG) trailers were noted
7 in applicable estimates. Each project as outlined was determined
8 to have either a “high,” “medium,” or “low” clearance cost and
9 typical values were assigned. For example, locations requiring
10 LNG/CNG trailers, cross compression, or temporary bypass would
11 constitute a high clearance cost.

12 **(5) Land, Permit, Environmental and Safety**

13 Sites with a large impact area or within public ROW are
14 assumed to have a large land, permit, environmental and safety
15 cost. Items included in the estimate are dollars for handling items
16 such as environmental biological issues, storm water pollution
17 prevention plans and groundwater mitigation, shoring, additional
18 temporary work area protection, and traffic control. Minimal real
19 estate costs for working space, or temporary easements, were
20 outlined in each work estimate.

21 Each project as outlined was determined to have a “high” or
22 “low” land, permit, environment and safety cost and typical values
23 were assigned for each. Land costs within an existing station were
24 assumed to be zero.

25 **(6) Power Supply, Telecommunication, and SCADA**

26 Cost estimates took into account whether the selected site has
27 existing power, telecommunication, and SCADA infrastructure to
28 accommodate the valve automation.

29 **(7) District Regulator Station Retrofits**

30 In order to ensure gas from distribution systems do not
31 backfeed gas into an isolated transmission line segment in cases
32 where the automated valves are actuated, evaluation and potential

1 modifications to District Regulator Stations was included. A unit
2 cost was applied for each identified location.

3 **(8) Adjacent Valve Projects**

4 In areas where multiple valves are located within the limits of
5 construction, a gain in labor efficiency is recognized for each
6 automated valve. Locations were reviewed and a multiplier of 0.35
7 for additional valve assemblies within the same site. The largest
8 valve size was assumed to be the primary location and a multiplier
9 of 1.0 used for that particular valve assembly.

10 **c. Engineering and Other Non-Construction Labor**

11 **(1) Engineering**

12 Work items such as preliminary engineering and design,
13 survey, subsurface utility engineering work, geotechnical study as
14 well as the land and environmental investigations were included
15 based on the scope of each individual site. SCADA/RTU
16 programming, mapping, records updates and estimating were also
17 incorporated in to the cost for all locations.

18 Each project was determined to require either “major” or
19 “minor” design engineering. A unit cost was applied for
20 SCADA/RTU programming of each RTU device. Mapping and
21 records updates relative to the project were assigned a unit cost
22 per project.

23 **(2) Project Management**

24 The costs associated with the management of individual
25 projects were estimated at 4 percent of the project engineering,
26 material and construction direct costs. These include project
27 manager and project controls costs associated with the planning,
28 monitoring and tracking of specific project tasks, and the PG&E
29 oversight of various contractors working on specific projects to
30 ensure work quality and efficiency.

31 **(3) Customer Outreach**

32 The valve automation work will require significant customer and
33 community outreach to notify and educate affected customers of

1 any work that may impact them and address any concerns they
2 may have. The objectives of customer and community outreach for
3 the Valve Automation Program are to:

- 4 • Ensure local government officials, customers and communities
5 are well informed about PG&E's Valve Automation Program and
6 educated about field activities before, during, and after work that
7 may impact them.
- 8 • Provide multiple ways for customers to get answers to their
9 questions, particularly regarding any safety concerns. Ensure
10 ongoing two-way communications between PG&E and local
11 customers and the community.
- 12 • Initiate outreach well ahead of visible PG&E onsite presence.
13 Ensure there are no surprises to local officials, customers and
14 the community.

15 A cost adder of 0.54 percent was applied to each project to
16 reflect the expenses associated with integrated customer and
17 community outreach. Key characteristics, methods of outreach,
18 and nature of expenses are described in more detail in Chapter 3.

19 **(4) Program Management Office**

20 Due to the nature and size of the Implementation Plan effort,
21 PG&E has retained an independent contractor to run a Program
22 Management Office (PMO) to ensure successful implementation of
23 this plan. The PMO is responsible for overall program
24 management including that of the Valve Automation Program.
25 PMO costs are not included in the individual project cost estimates
26 and are addressed at the program level. Information about PMO
27 costs, and the roles and responsibilities of the PMO, are included in
28 Chapter 7.

29 **7. Indirect Cost**

30 Indirect cost percentages were applied to each project in accordance
31 with PG&E guidelines. Costs associated with handling, storage, and
32 procurement of material were calculated to be 29 percent of the overall
33 estimated material costs.

1 Costs assumed an Allowance for Funds Used During Construction rate
2 of 5.24 percent of total project costs. This rate was used based on
3 anticipated project duration, for engineering and construction, of
4 13-18 months.

5 **8. Contingency**

6 No contingency was included in individual cost estimates. Contingency
7 is addressed on a program level, and is discussed in Chapter 7.

8 Based upon the cost estimates being derived from only preliminary
9 project definition, and the level of cost estimating uncertainty, contingency
10 usage will likely be required on a number of projects. Contingency usage
11 will be required if additional design details are discovered during the
12 engineering phase that result in additional valve replacements and/or
13 expanded piping construction work.

14 **9. Metering Cost Estimates**

15 Flow Metering cost estimates assumed a typical clamp-on ultrasonic
16 operational meter installation based upon PG&E historical costs. It was
17 assumed that the clamp-on meter would be installed on below ground pipe
18 inside of a new vault with the required associated instrumentation installed
19 above ground. The same overheads were applied as for the valve
20 automation work.

21 **10. Other Cost Estimates**

22 **a. SCADA Enhancement Projects**

23 The cost for SCADA Enhancements was determined based upon
24 the knowledge and experience of PG&E subject matter experts on the
25 subject and PG&E historical costs of similar efforts where available.
26 These were confirmed as reasonable by contractors with SCADA
27 system subject matter expertise. The costs of these enhancements are
28 primarily an expense cost. Costs were estimated for the following
29 distinct efforts:

- 30 • Comprehensive review of existing SCADA system and best
31 practices industry review.
- 32 • Additional SCADA screen development and implementation for
33 enabling operators to identify and evaluate an emergency event.

- 1 • Adding valve position data points to SCADA for valves most likely to
2 affect pipeline configuration (capital) and development and
3 implementation of an electronic pin map for valve position indication
4 for key manual valves not currently on SCADA (expense).
- 5 • Development and implementation of pipeline shutdown plans and
6 protocols, including creation of specific pipeline shutdown SCADA
7 screens for each automated pipe segment.
- 8 • Development and implementation of a gas control operator training
9 program specific to the use of all new tools and processes in line
10 rupture identification and response.
- 11 • Development and implementation of alarm management, advanced
12 situational awareness composite alarm logic and filtering
13 applications, and situational awareness overview screens.
- 14 • Development and implementation of linkage between GIS system
15 and gas SCADA data system.
- 16 • Assessment of online pipeline simulator technology which would
17 assess pipeline operating conditions on a real-time basis for
18 abnormalities.
- 19 • Research, evaluation and testing of various leak, pipeline damage
20 and ground movement detection technologies that could be
21 integrated with SCADA.
- 22 • Research, evaluation and testing of redundant communication
23 technologies that could be employed in communicating between
24 field sites and Control Centers.

25 **b. Operation and Maintenance Additions**

26 For every new automated valve and meter that will be installed there
27 will be additional maintenance above and beyond what is required for a
28 manual valve. This is a result of the additional communications,
29 instrumentation, and controls equipment required by the automation.
30 Maintenance associated with an automated valve that is additional to
31 that required for a manual valve includes:

- 1 • Performing calibration and accuracy verification for the pressure
2 transmitters.
- 3 • Performing inspection and testing of the SCADA RTU for
4 communicating with the valve.
- 5 • Performing annual inspection of the instrumentation and control
6 equipment used in valve automation and control including the valve
7 actuator, valve position switches, solenoid valves, local control
8 panel and other auxiliary equipment associated with valve control.
- 9 • Performing full end to end operability testing of the remote controls
10 for automated isolation valves (new requirement that will apply to all
11 existing and new automated isolation valves).

12 The additional automated valve maintenance is on average
13 expected to require an additional eight (8) hours per valve per year. The
14 electronic pin map system will also require scheduled valve position field
15 verifications for all key manual valves included in this system to ensure
16 its accuracy.

17 Additionally, there will be a one-time expense charge to develop a
18 formal technician training program for automated isolation valve
19 operation and maintenance. This will be a one day class that
20 approximately 200 field technicians will be required to take. Also
21 proposed is an annual pipe segment shutdown training requirement for
22 all gas maintenance field personnel.

23 For every new operational flow meter that will be installed, there will
24 also be maintenance required for this equipment. This includes
25 calibration and verification of the transmitters associated with flow
26 calculation and performing meter diagnostics to verify accurate
27 operation on a twice per year basis. The maintenance required for each
28 new operational flow meter is expected to be four (4) hours per every
29 six-month maintenance visit per meter. There is also forecasted to be
30 one additional technical specialist required to provide ongoing support
31 and training to field personnel on automated valves, RTUs, and
32 operational meters.

1 Besides additional field maintenance and operations costs, there will
2 be additional operating costs to Gas Control Operations associated with
3 the addition of 185 automated valves (including valve position indication
4 for each valve on SCADA), 40 new RTU sites and approximately
5 300 new pressure points, and the associated supervisory control and
6 alarms associated with this equipment, as well as the operating costs
7 associated with increased gas system monitoring, system verification
8 and testing. The increased operating requirements is estimated to result
9 in the need for an additional manned operational control room desk
10 within Gas Control, and the need to increase Gas Control staffing by
11 three additional persons to manage this desk. In addition, all Gas
12 Control Transmission Coordinators and Operators will have additional
13 annual training associated with the required increased level of
14 preparedness to identify and respond to rupture events, and with the
15 additional tools and processes to accomplish enhanced response. Unit
16 costs of \$125 per man-hour for operations personnel and \$140 per
17 man-hour for maintenance personnel were used in the cost estimates.

18 **J. Summary of Program Costs**

19 **1. Cost Forecast Summary (Phase 1)**

20 PG&E established new Major Work Categories (MWC) to consolidate
21 and categorize expenditures by asset and work activities. The MWCs are
22 further broken down into subcategories called Maintenance Activity Type
23 (MAT) codes, to group similar work together. The MWCs and MATs used
24 by PG&E to define the Valve Automation Program projects are discussed
25 below.

26 Category MWC-2H includes all valve automation, metering and valve
27 position remote monitoring capital installations, except for the portion of the
28 work benefitting Standard Pacific Gas Line Inc. (StanPac) facilities. The
29 MAT code associated with all MWC-2H work is 2H3, Valve Automation
30 capital work. The Valve Automation capital work associated with StanPac
31 facilities is included in MWC-44A with the same MAT code as the MWC.

32 Category MWC-KE includes all expenses associated with the Valve
33 Automation Program development, the SCADA enhancement projects and

1 Valve Automation training development projects, as well as the reoccurring
 2 incremental maintenance and operating costs resulting from the
 3 implementation of the Valve Automation Program. The MAT code
 4 associated with all of this work is KE4, Station Other, except for the Program
 5 development costs which are included under MAT code KEX, Pipeline
 6 Other.

7 Detailed information about the scope and estimated cost of individual
 8 projects within the Valve Automation Program is included in the Workpapers
 9 Supporting Chapter 4.

10 2. Forecast Capital Expenditures (Phase 1)

11 The following table outlines the Valve Automation Program capital
 12 expenditures forecast by year necessary to execute the Phase 1 scope of
 13 work.

TABLE 4-5
PACIFIC GAS AND ELECTRIC COMPANY
VALVE AUTOMATION PROGRAM, PHASE 1 (2011-2014)
CAPITAL EXPENDITURES
\$ IN MILLIONS (NOMINAL)

Line No.	MAT Work Category	2011(a)	2012	2013	2014	Total
1	MAT-2H3	\$13.7	\$37.5	\$48.7	\$26.0	\$125.9
2	MAT-44A (StanPac)	–	2.0	4.6	–	6.6
3	Total	\$13.7	\$39.5	\$53.3	\$26.0	\$132.5

(a) The capital related costs (including depreciation, taxes and return) for capital projects forecast to be operational in 2011 will be funded by shareholders, as described in Chapter 8.

14 a. Valve Automation Projects

15 Eighty (80) separate valve automation projects will be implemented
 16 in Phase 1 within 11 geographical areas. The forecast capital
 17 expenditures by area and year are outlined in the following table:

TABLE 4-6
PACIFIC GAS AND ELECTRIC COMPANY
VALVE AUTOMATION PROGRAM, PHASE 1 (2011-2014)
CAPITAL EXPENDITURES – WORK BY AREA
\$ IN MILLIONS (NOMINAL)

Line No.	Geographical Area	2011(a)	2012	2013	2014	Total
1	SF Peninsula (Launch)	\$13.3	\$0.4	–	–	\$13.7
2	SF Peninsula (Remainder)	0.3	25.6	\$0.9	–	26.8
3	San Jose Area	–	4.2	3.3	–	7.5
4	Antioch to Richmond (PG&E)	–	2.9	8.3	–	11.3
5	Antioch to Richmond (SP)	–	1.9	4.6	–	6.6
6	Oakland to Fremont to Livermore	–	0.2	16.9	\$0.5	17.7
7	Brentwood Area	–	–	6.8	0.6	7.4
8	Sacramento Area	–	–	2.9	4.2	7.1
9	Vallejo-Fairfield Area	–	–	3.0	5.7	8.7
10	Stockton-Modesto Area	–	–	0.9	6.6	7.4
11	Bakersfield Area	–	–	–	2.5	2.5
12	Eureka Area	–	–	–	0.9	0.9
13	Barstow Area	–	–	–	1.5	1.5
14	Total	\$13.6	\$35.4	\$47.8	\$22.5	\$119.3

(a) The 2011 capital related costs (including depreciation, taxes and return) for capital projects forecast to be operational in 2011 will be funded by shareholders, as described in Chapter 8.

1 b. Other Capital Projects

2 Other Phase 1 capital projects includes the installation of thirty (30)
3 operational flow meters at various locations and the installation of
4 remote valve position monitoring capability on approximately fifty (50)
5 manually operated valves at various locations. The forecast cost by
6 year of these installations is outlined in the following table:

TABLE 4-7
PACIFIC GAS AND ELECTRIC COMPANY
VALVE AUTOMATION PROGRAM,
PHASE 1 (2011-2014)
CAPITAL EXPENDITURES – OTHER CAPITAL PROJECTS
\$ IN MILLIONS (NOMINAL)

Line No.	Work Type	2011(a)	2012	2013	2014	Total
1	Flow Meter Installations	–	\$3.9	\$5.3	\$3.3	\$12.5
2	Valve Position Remote Monitoring	\$0.1	0.2	0.2	0.2	0.7
3	Total	\$0.1	\$4.1	\$5.5	\$3.5	\$13.2

(a) The 2011 capital related costs (including depreciation, taxes and return) for capital projects forecast to be operational in 2011 will be funded by shareholders, as described in Chapter 8.

1 **3. Forecast Expenses (Phase 1)**

2 **a. Valve Automation Program Development**

3 Valve Automation Program development costs includes contractor
4 and incremental PG&E labor costs to review industry practices on
5 RCV/ASV usage and available technology for RCV/ASV implementation,
6 perform benchmarking of domestic and international companies on
7 RCV/ASV usage, evaluate firefighting capabilities and impacts of
8 various intensity natural gas fueled fires, develop criteria for RCV/ASV
9 usage for PG&E's gas transmission system, identify pipe segments
10 meeting the developed criteria, develop a unit cost estimating
11 methodology for segments to be automated, and evaluating and cost
12 estimating Phase 1 pipe segments identified for automation.

13 The forecast cost by year for development of the Valve Automation
14 Program, all of which is being incurred in 2011, is outlined in the
15 following table:

**TABLE 4-8
PACIFIC GAS AND ELECTRIC COMPANY
VALVE AUTOMATION PROGRAM, PHASE 1 (2011-2014)
EXPENSE PROJECTS – PIPELINE OTHER
\$ IN MILLIONS (NOMINAL)**

Line No.	MAT Work Category	2011(a)	2012	2013	2014	Total
1	Pipeline Other, MAT-KEX	\$0.8	–	–	–	\$0.8

(a) The 2011 expenses will be funded by shareholders, as described in Chapter 8.

16 **b. SCADA Enhancements and Valve Automation Expense Projects**

17 SCADA enhancement and valve automation expense projects
18 consist primarily of efforts to develop new tools, processes and training
19 for identification and response to pipeline ruptures by PG&E's System
20 Gas Control Center and work to evaluate new technologies that could
21 be utilized in detecting abnormal operating events. The forecast cost by
22 year for implementation of these projects is outlined in the following
23 table:

**TABLE 4-9
PACIFIC GAS AND ELECTRIC COMPANY
VALVE AUTOMATION PROGRAM, PHASE 1 (2011-2014)
EXPENSE PROJECTS – STATION OTHER
\$ IN MILLIONS (NOMINAL)**

Line No.	MAT Work Category	2011(a)	2012	2013	2014	Total
1	Station Other, MAT-KE4	\$0.8	\$1.8	\$1.8	\$2.2	\$6.6

(a) The 2011 expenses will be funded by shareholders, as described in Chapter 8.

1 c. Reoccurring Operations and Maintenance Costs (M&C, Gas Control)

2 The implementation of the various capital and expense projects will
3 result in additional ongoing Operations and Maintenance (O&M)
4 expense. This includes increased O&M costs for maintenance,
5 inspection, testing and system monitoring and operations. The forecast
6 cost by year for these annually reoccurring costs during the Phase 1
7 time period of 2011-2014 is outlined in the following table:

**TABLE 4-10
PACIFIC GAS AND ELECTRIC COMPANY
VALVE AUTOMATION PROGRAM, PHASE 1 (2011-2014)
REOCCURRING O&M EXPENSES – STATION OTHER
\$ IN MILLIONS(NOMINAL)**

Line No.	MAT Work Category	2011(a)	2012	2013	2014	Total
1	Station Other, MAT-KE4	–	\$0.8	\$1.3	\$1.6	\$3.7

(a) The 2011 expenses will be funded by shareholders, as described in Chapter 8.

8 K. Project Implementation (Phase 1)

9 1. Scheduling of Work

10 PG&E expects to complete approximately 80 separate valve automation
11 projects, as well as a project to install additional flow metering, during
12 Phase 1. PG&E has created a proposed preliminary schedule for work
13 execution. This schedule and future modifications are based upon the
14 following considerations:

- 15 • Population density and concentration of high PIR pipelines.

- 1 • Minimization of operational impact to the gas transmission system and
2 service impacts to customers.
- 3 • Value and work efficiencies of coordinating work together by pipeline
4 and geographical area.
- 5 • Coordination with other scheduled pipeline work including pipe
6 replacements, station rebuilds, ILI, and strength testing of pipeline
7 segments.

8 The flow metering installations will be implemented in conjunction with
9 the valve automation work planned for specific pipelines and station
10 facilities.

11 **2. Implementation Schedule**

12 Engineering of an early launch of Phase 1 valve automation projects is
13 underway with construction scheduled for the second half of 2011.

14 Executing this set of eight projects on the San Francisco Peninsula will
15 provide us with knowledge to fine tune our implementation plan to optimize
16 work execution. After the early launch set of projects, current plans are for
17 beginning engineering on nine projects each quarter beginning in the second
18 half of 2011, with each project then having a 15-month duration to engineer,
19 construct, and place into operation. The following table provides the
20 planned start and operative dates for the eighty (80) valve automation
21 projects by geographical area:

**TABLE 4-11
PACIFIC GAS AND ELECTRIC COMPANY
VALVE AUTOMATION PROGRAM, PHASE 1 (2011-2014)
WORK EXECUTION BY AREA**

Line No.	Geographical Area	Start	Operational Date	Total Projects
1	Peninsula (2011 Construction)	2011	2011	8
2	Peninsula (2012 Construction)	2011	2012	14
3	San Jose Area	2011 & 2012	2012 & 2013	7
4	Antioch to Richmond	2012	2013	11
5	Oakland to Fremont to Livermore	2012	2013	13
6	Brentwood Area	2012	2013	4
7	Sacramento Area	2013	2014	4
8	Vallejo-Fairfield Area	2013	2014	5
9	Stockton-Modesto Area	2013	2014	7
10	Bakersfield Area	2013	2014	3
11	Eureka Area	2013	2014	2
12	Barstow Area	2013	2014	2

1 All Phase 1 Valve Automation work is forecasted to be complete by the
2 end of 2014. Phase 2 projects are planned to begin engineering during
3 2014.

4 **3. Need for Plan Modifications and Work Re-Prioritization**

5 The Valve Automation Program will evaluate changes to class location
6 and HCA of pipe segments as new information becomes available to identify
7 potential changes to the initial list of pipe segments included in the plan for
8 automation. The total number of valves requiring automation and those
9 requiring replacement may require adjustment as detailed engineering is
10 completed on specific projects. Any adjustments should be only minor in
11 nature.

12 Work will be closely coordinated with other capital and expense
13 budgeted work both within the GT&S rate case and within other parts of the
14 Implementation Plan. If plans for other work changes or new projects are
15 added, the Valve Automation Program will adjust its work plan to effectively
16 and efficiently manage the program.

17 Program changes will be recorded and reported to the CPUC
18 bi-annually.

19 **4. Quality Assurance and Quality Control**

20 All PG&E gas transmission labor, construction, and materials
21 procurement work is performed to the highest quality and sound

1 professional procedures and practices, and in conformance with all PG&E
2 Gas Standards and Work Procedures, U.S. DOT regulation 49 CFR
3 Part 192, including DOT operator qualifications and drug and alcohol testing,
4 API 1104 and 5L standards, Occupational Safety and Health Administration
5 (OSHA) and California OSHA (Cal-OSHA) requirements, and any federal,
6 state and local laws, rules, regulations and ordinances.

7 To ensure work quality, PG&E is instituting a Quality Assurance and
8 Quality Control (QA/QC) program to oversee construction activities for
9 Implementation Plan projects. This QA/QC program will be similar to the
10 new QA/QC program PG&E developed for gas transmission pipeline
11 construction.

12 Quality Assurance is the means of assuring that the QC methods PG&E
13 employs are effective in ensuring compliance with all applicable design
14 standards. The QA team monitors construction activities on pre-determined
15 sampling frequencies, making adjustments to the frequencies as needed
16 based on gathered results.

17 Quality Control refers to the operational activities put in place to control
18 the quality of a product or service, and is further defined as the routine and
19 systematic inspections conducted to verify that each phase of the work
20 meets or exceeds the minimum design requirements. The QC
21 activities/processes will be consistently monitored by QC inspectors capable
22 of ensuring the work is being done in accordance with the drawings and
23 applicable standards.

24 **L. Conclusion**

25 In summary, the capital expenditures and expenses presented in this
26 chapter will allow PG&E to provide automated isolation capability for all large
27 diameter, high pressure, gas transmission pipelines in Class 3 HCA areas and
28 all gas transmission pipelines in Class 4 areas. The expenditures also allow
29 PG&E to provide automatic shut-off capability on large diameter, high pressure,
30 pipelines in populated areas that cross active earthquake faults that represent a
31 rupture threat to these lines. Additionally, the expenditures allow PG&E to
32 enhance its SCADA system and Gas Control operations to provide additional
33 tools and training for minimizing the time to detect and respond to a pipeline
34 rupture. PG&E believes that the forecasted capital expenditures and expenses

1 contained herein are reasonable, prudent, and should be approved by the CPUC
2 for implementation and cost recovery. Implementation of the Valve Automation
3 Program will facilitate emergency response in the event of a pipeline rupture,
4 thereby reducing potential threat and the impact on the public and property.