

Lafayette Gas Safety Risk Management

Lafayette Gas Safety Alliance Meeting

May 28, 2019



Together, Building
a Better California




Pipeline Safety Risk Management in Lafayette - Agenda

- Lafayette Transmission and Distribution Assets
- Review of PG&E risk informed work planning process
- Transmission Pipeline Threats, Risks and Risk Mitigation
- Distribution Asset Threats and Risks
 - Distribution Risk Mitigations held for future discussion



Lafayette Transmission Pipelines





Lafayette Transmission Pipeline Assets Summary

➤ Lafayette Transmission Pipeline Assets Summary

- **Lines:** 191-1, 191A, 191B, DFM 3001-01 and DFM 3002-01
- **Miles of Pipeline:** approx. 10.9 miles
- **Miles of HCA:** approx. 2.9 miles
- **Material:** Steel
- **Maximum Allowable Operating Pressure (MAOP) Range:** 60 psig to 338 psig
- **Operating Safety Margin:** Maximum MAOP at less than 23% of design
- **Pipe install Years:** 1947 to 2013

Diameter (inch)	Transmission Pipe Pressure by % Design (Miles)				Total
	> 0% to < 10%	≥ 10% to < 15%	≥ 15% to < 20%	≥ 20% to < 23%	
3.500	<0.01	0.02	0.00	0.00	0.02
4.500	0.14	0.00	0.71	0.00	0.85
6.625	1.63	<0.01	0.00	0.00	1.63
8.625	0.28	1.79	0.26	0.00	2.33
10.750	0.00	1.65	<0.01	0.00	1.65
12.750	<0.01	3.41	0.40	<0.01	3.81
16.000	0.00	0.00	<0.01	0.63	0.63
Totals:	2.05	6.86	1.37	0.63	10.9

Year Range	Miles
1947 - 1960	5.60
1961 - 1970	4.47
1971 - 1980	0.03
1981 - 1990	0.57
1991 - 2000	0.01
2001 - 2010	0.16
2011 - 2019	0.06
Total:	10.9



Lafayette Distribution Pipeline Assets Summary

➤ Lafayette Distribution System Assets Summary

Distribution Mains

- Distribution Mains Materials: Steel (~75%), Plastic

Material	Distribution Mains Diameter Ranges (inches)				Totals
	Unknown	<=2	>2" to ≤ 4"	> 4" to ≤ 8"	
Aldyl-A polyethylene	0.0	23.4	0.6	0.0	24.0
Other polyethylene	0.0	9.6	3.2	0.5	13.3
Steel, 1941-1972	0.0	76.8	16.2	7.7	100.7
Steel, post-1972	0.0	3.7	0.6	0.2	4.5
Steel, pre-1941	0.1	7.3	1.4	0.4	9.2
Totals	0.1	120.8	22.1	8.8	151.8

Distribution Services


- Distribution Services Materials: Plastic (~56%), Steel (~44%), Copper (~0.1%)

Distribution Services	
Material	Count
Plastic	5,425
Copper	19
Steel	4,267
Total	9,710

Asset Type	Install Year									Totals
	Pre-1940	1940-1949	1950-1959	1960-1969	1970-1979	1980-1989	1990-1999	2000-2009	2010-2019	
Main Mileage	7.2	33.2	37.2	26.9	17.4	14.1	6.6	3.2	6.0	151.8
Counts of Services	2,794	261	1,358	1,160	671	621	754	376	1,714	9,710



Review of Risk Informed Work Planning





Transmission Pipeline Threats

Steel Pipe External Corrosion (EC)	Steel Pipe Internal Corrosion (IC)	Steel Pipe Stress Corrosion Cracking (SCC)	Steel Pipe Manufacturing and Construction	Steel Pipe Equipment and Incorrect Operations	Steel Pipe Third-Party Damage (TPD)	Steel Pipe Weather-related and Outside Forces (WROF)	Plastic Pipe threats	
External Corrosion	Internal Corrosion	High-pH Axial SCC	Manufacturing Seam defect	Over-pressure due to Equipment Failure	Excavation Damage	Seismic Fault Crossing	Manufacturing	
		Near Neutral-pH Axial SCC	Manufacturing Body defect	Over-pressure due to Incorrect Operations		Slope Instability	Vegetation Impact (Tree root)	Construction
		Circumferential SCC	Construction defect			Liquefaction	Tsunami	Equipment
						Erosion	Third-Party damage	
						Lightning	Incorrect Operations	
						Frost	Weather-related and Outside Forces (WROF)	
						Heavy Rain or Floods		
						Arc Strike		




Distribution Pipe Threats

Corrosion	Excavation	Material & Weld	Incorrect Operation	Natural Force	Other Outside Force	Equipment Failure	Other
Internal	Excavation	Plastic material failure	Crossbore	Earth Movement	Fire/explosion	Equipment malfunction	Other
External			Fusion failure		Rodents		
Atmospheric		Metallic material failure	Weld failure	Earthquake	Previous damage	Pipe Dope	
		Compression coupling	Incorrect operation	Flood	Electrical facilities		
			Construction defect	Lightning	Third party		
				Root damage	Vandalism		
				Tsunami	Vehicle		
				Other natural forces			



Transmission Pipe Risks - Lafayette




➤ Between 1986 and 2018 there were no PHMSA reportable incidents on Transmission in Lafayette.

2 parts per million per manufacture threat



Threat Matrix (Transmission Pipe)

Approved: 07/17/18



availability and the quality of the asset data



--- = Mitigation for Interacting Threat

TRA# - Risk Register Name

Mitigation Color Key

Green	= Meets or exceeds industry best practices AND controls are adequate
Amber	= Partially meets industry best practices OR controls are being strengthened
Red	= Does not meet industry best practices AND current controls are not adequate
White	= Pending Evaluation
	*Not yet implemented



2019 GT&S Risk Placemat (Transmission)

2019 GT&S Rate Case - Risk Mitigation Summary "Placemat"

Risk Category		Loss of Containment				Loss of Supply & Service			Inadequate Response & Recovery	
Threat / Work Classification		Time-Dependent Threats	Stable / Resident Threats		Time Independent Threats		Capacity and / or Reliability Threats		Emergency Response	
		"The threat level may grow over time if unchecked"	"The threat is inherent but does not grow over time unless acted upon by pressure or external load"		"The threat exists outside of the continuum of time"		"Inability to meet our obligation to serve"		"Preparedness to respond to incidents in a timely manner"	
Capital	Expense	External Corrosion, Internal Corrosion and Stress Corrosion Cracking*		Manufacturing Related Defects, Welding / Fabrication Related and Equipment Related*		3rd Party / Mechanical Damage, Incorrect Operations and Weather-Related & Outside Forces*		Physical System Constraints, Equipment Limitations	System Control Limitations, Inproper Training and Coordination	
\$971	\$648									
Targeted Mitigations	Corrosion Control	Direct Assessment	Vintage Pipe Replacement	Station Systems and Components Replacement	Exposed & Shallow Pipe (including Water and Levee Crossings)	Locate & Mark	Capacity	Work Requested by Others	Gas System Operations	
	Chapter 8	Chapter 5	Chapter 5	Chapter 7	Chapter 5	Chapter 9	Chapter 10	Chapter 5	Chapter 10	
	79.1	35.3	40.6	76.1	21.7	13.2	70.0	27.9	22.2	
	-	-	-	19.1	0.9	-	6.2	0.7	-	
	Gas Quality Assessments	Hydrostatic Testing		Station Rebuilds	Geo-Hazard Monitoring & Mitigation	Earthquake Fault Crossing	New Business	Class Location Program	Valve Automation	
	Chapter 7	Chapter 5		Chapter 7	Chapter 5	Chapter 5	Chapter 10	Chapter 5	Chapter 5	
	-	1.0	46.0	151.0	44.7	4.5	2.8	12.2	1.4	29.5
	-	-	-	-	-	-	-	4.7	5.5	-
	Leak Management	Storage Assessments	Station Assessments & Strength Tests	FIMP Implementation and Documentation		Physical Security	LNG/CNG		Public Awareness	
	Chapter 9	Chapter 6	Chapter 7	Chapter 7		Chapter 7	Chapter 5		Chapter 5	
-	6.1	10.8	0.3		5.7	3.7	2.8	4.4		
Storage Well Reworks	Storage Repair & Replace	Storage Controls & Monitoring	Compressor Replacements					Valve Program		
Chapter 6	Chapter 6	Chapter 6	Chapter 7					Chapter 5		
160.3	3.2	14.5	21.5					25.9		
			In-Line-Inspection					SCADA		
			Chapter 5					Chapter 10		
			213.5					2.7		
			124.5							
			Programs to Enhance Integrity Management							
			Chapter 5							
			14.2							
					Operations & Maintenance					
					Chapter 9					
					-					
					46.6					
					Research & Development					
					Chapter 12					
					-					
					2.9					
Capital	Expense			Other Pipeline Safety and Reliability Pipe Replacements						
924.9	522.6			Chapter 5						
				7.4						
				4.1						
				Information Technology						
				Chapter 12						
				30.4						
				20.4						
				Other GT&S Work						
				Chapters 10 and 13						
				6.1						
				91.8						
				StanPac						
				Chapters 5, 7, 8, 9						
				6.0						
				4.5						
				Gas Gathering						
				Chapter 5						
				4.0						
				-						
Capital	Expense			Pipe Investigations and Field Engineering						
46.6	125.4			Chapter 5						
				-						
				8.7						



Corrosion Control Program

- PG&E uses an active cathodic protection (CP) system on its gas transmission and steel distribution pipelines to protect them against external corrosion.
- CP systems inspected annually to ensure they are operating correctly.
- Inspections of the cathodic protection systems on the lines in Lafayette took place in September 2018 and February 2019 and were found to be operating correctly.



Public Awareness Program (Damage Prevention)

- Along with Patrolling/Continuing Surveillance, Locate and Mark, Pipeline signs, shallow pipe program, and the ILI program, the Damage Prevention portion of the Public Awareness program is a key mitigation program for prevention of 3rd party excavation damage.

- 3rd Party Excavation Damage is the leading cause of PG&E's significant incidents reported to PHMSA. *systemwide*
 - *Transmission: 93%*
 - *Distribution: 38%*

- More than half of 3rd party dig-ins in Lafayette caused by no USA ticket called or expired USA ticket
 - *All dig-ins on Distribution, over 95% on Distribution Services* *5% transmission*
 - *Nearly 90% of the 3rd party dig-ins in residential locations.*
 - *PG&E's USA ticket counts have increased nearly 50% since 2013*




Customer and Public Safety Communications

- Bill Inserts and E-Campaigns
 - Businesses and residents within PG&E service territory who receive a gas bill
- Asset Specific Mailings
 - Businesses and residents within proximity to Storage or compressor facility, transmission pipeline, un-odorized pipeline
- Customer Specific Mailings
 - Core gas customers and Master Meter account holders
- School Outreach
 - School administrators and district officials within PG&E's service territory



- Excavator Newsletter
 - Companies performing excavation work in California and companies involved in land development and planning in California
- Pipeline Emergency Response Guidelines
 - Local, state or regional officials and agencies with public safety jurisdiction within PG&E's service territory
- Public Officials Newsletter
 - Local, city, county and state officials located within PG&E's gas service territory





Customer and Public Safety Additional Targeted Communications

- Farmer Mailing
 - individuals and companies who own or operate a farm or ranch within PG&E's service territory
- Landscaper Mailing
 - plumbing, fencing, and landscaping companies within PG&E's service territory
- Homeowners Associations Mailing
 - HOA officers and agents within PG&E's service territory
- Social media campaigns
 - Targeted areas with high damages
- Children's safety campaign
 - Downloadable gas and electric safety activity sheets for children

The collage features three main pieces of communication:

- Top Flyer: "Get home safely / Llegue seguro a casa"**
 - Locate overhead lines / Localice la ubicación de los cables aéreos:** Survey your work site to find overhead power lines, poles and wires, including lines that run from poles to homes and businesses. Power lines are not insulated. Touching any overhead or underground electric line can cause serious injuries and damage machinery.
 - Identificar los procedimientos para avisar a los empleados de su empresa, clientes y proveedores.
 - Es muy importante que los empleados usen equipo de protección personal que sea seguro.
 - Dig and plant safely / Excave y siembre de manera segura:** Call 811 or visit 811.org before you dig and plant. California law requires you to use this FREE service. Mark your project area in white. Leave all colored flags, stakes or paint marking underground lines in place until you finish digging. These markers, placed by utility companies, are valid for 28 days. Use hand-held digging tools when working within 24 inches of the outside edge of any underground lines.
 - Lláme al 811 o visite el sitio 811.org dos días hábiles antes de excavar y sembrar. La ley en California exige que usted haga uso de este servicio GRATIS de una sola llamada. Marque el área del proyecto en blanco. Déje en su lugar todas las banderitas de colores, estacas o señalizaciones que indiquen la ubicación de las tuberías subterráneas hasta terminar la excavación. Estos marcadores, colocados por las compañías de servicios públicos, tienen una vigencia de 28 días. Use herramientas de mano al excavar a una distancia de 24 pulgadas o menos del borde exterior de cualquier tubería subterránea.
 - Color code for marking underground utility lines / Cierre de colores para marcar las líneas subterráneas de los servicios públicos:** Includes a color key for marking lines: PROPOSED EXCAVATION (Yellow), EXISTING GAS (Red), EXISTING WATER (Blue), EXISTING SLOPE (Green), EXISTING TELEPHONE (Black), EXISTING CABLE TV (Purple), EXISTING FIBER OPTIC (Orange).
 - Spot a natural gas leak / Detecte una fuga de gas natural:** Natural gas pipeline leaks can occur due to corrosion or unsafe excavation and may lead to explosions. Natural gas service includes fire, property damage or serious injury.
 - Smell: Smelling a "rotten egg" odor means an indication of a gas leak due to the odorant we add for your safety.
 - Sound: Listen for hissing, whistling or roaring sounds coming from underground or gas meter areas.
 - Visual: Look for dirt blowing into the air, bubbling in a pond or creek and dead-flying vegetation in an otherwise moist area.
 - Respond to a gas leak:** (Section header)
- Middle Social Media Post:** Pacific Gas and Electric Company shared a link. April 21 at 9:52pm. "Time to garden? Contact 811 before you dig or plant." It's FREE! Utilities will mark underground lines. 811EXPRESS.COM. 32 shares, 7 Comments.
- Bottom Flyer: "Safety tips for Homeowner Associations and their members"** Encuentre consejos en español en la página 9.



Excavation Damage – How Can Lafayette Help?


- Encourage the City of Lafayette to become a Gold Shovel City.
<http://goldshovelstandard.org/>
- Hire a Compliance Officer who will patrol the city and ensure anyone conducting excavation work has a valid permit and a valid USA ticket.
- Work with landscape companies, fencing companies, and homeowners and 811 to offer free safe digging classes.
- Partner with gardening clubs, rental companies, and other stakeholders to Sponsor 8-1-1 day events every August 11th.
- Sponsor and support safe digging day every Arbor Day.
 - *Provide education booths to select the right tree/plants around power lines and underground infrastructure) and include 811 training.*



Strength Testing Program

- Mitigate resident manufacturing threats and Stress Corrosion Cracking (SCC) by strength testing the pipe to confirm the pipe's integrity.
 - *Validate the integrity and assure a margin of safety for those gas transmission pipelines that lack a documented strength test record that is traceable, verifiable or complete (TVC).*

Lafayette Strength Testing



- TVC Record of a Test
- HCA - No TVC Record of a Test
- Class 3 or 4, Non-HCA - No TVC Record of a Test
- New HCA - Trans Def. - No TVC Record of a Test
- Class 1 or 2, Non-HCA - No TVC Record of a Test

* Class 1/2 Non- HCA bundled with HCA and Class 3 tests as tests are completed



Transmission Valve Automation Program

- Enhances emergency response in the event of a gas transmission pipeline rupture.
 - *Valve Automation priority given to pipes greater than 12 inch diameter in HCAs and Class 3 and 4, non-HCA in order to achieve a response and isolation time less than a 1 hour.*
 - *For pipes less than or equal to 12 inch diameter, incident mitigation management approach is taken, primarily using local, manual valve closure for response and isolation.*

- Valve at Reliez Station near intersection of Reliez Valley road and Olympic Blvd. planned for automation in 2020.
 - *Upstream automated valve in Walnut Creek for isolation of 16" diameter line (4.8 miles away)*

- Remaining valves 4" to 12" diameter using incident mitigation management approach, using manual valve closure for response and isolation.



Geo-Hazard and Earthquake Fault Crossing Programs

- Addresses the Weather Related and Outside Force threat
 - *Seismic fault crossing, slope instability, liquefaction, erosion, lightning, frost, heavy rain/floods, subsidence, vegetation impact (tree root), tsunami, wind, vehicular damage, vandalism, arc strike*
- Geo-Hazard Threat Identification and Mitigation Program – land movement, including subsidence, slope instability, erosion, vegetation impact (tree root), heavy rain or floods, etc.
- Earthquake Fault Crossing Program – Seismic fault crossing and liquefaction.
- Both programs are enhanced/supported by PG&E's patrolling and continuing surveillance program
 - *Routinely identifies localized land movement, especially after rainfall events, using the information for risk prioritized local mitigations*



Integrity Assessments (Direct Assessment and ILI)

- ILI tools can address multiple threats.
 - *When a pipeline cannot be made piggable, the industry best practice is to use DA to look for time dependent threats, such as external corrosion.*
- ILI - most reliable pipeline integrity assessment tool currently available to transmission pipeline operators to assess the condition of pipe.
 - *Small diameters, low flow and low pressure inhibits the use of traditional tools in natural gas pipelines*
 - *Limited use of non-traditional, robotic and tractor tools.*
- Direct Assessment - Identify and assess locations likely to have corrosion
 - *Industry and code identified integrity assessment*

Route	Integrity Assessment			
	Prior Assessment	Results of Most Recent Assessment	Future Assessment	Description
191-1	ECDA (2013)	No issues requiring corrective action	Non-Traditional ILI (2020)	Switch from ECDA to Non-Traditional ILI, approximately 0.5 miles
191-1	Hydrotest (2012)	No issues requiring corrective action	Traditional ILI (2020)	Switch from Hydrotest to Traditional ILI, prior assessment approximately 0.5 miles, extending to approximately 0.6 miles for future assessment
191B	N/A	N/A	Non-Traditional ILI (2019)	Focused integrity assessment to address a WROF threat
3001-01	N/A	N/A	ECDA (by 2026)	Baseline integrity assessment, new HCA due Transmission definition change (approximately 0.3 miles)
3001-01	N/A	N/A	ECDA (by 2027)	Baseline integrity assessment, new HCA due Transmission definition change (approximately 0.1 miles)
3001-01	N/A	N/A	ECDA (by 2028)	Baseline integrity assessment, new HCA due Transmission definition change (approximately 0.2 miles)
3002-01	ECDA (2013)	No issues requiring corrective action	ECDA (2020)	Approximately 0.02 miles for prior assessment, extended to approximately 0.3 miles for future assessment
3002-01	N/A	N/A	ECDA (by 2026)	Baseline integrity assessment, new HCA due Transmission definition change (approximately 0.4 miles)

Questions?



Together, Building
a Better California